



- NOTES:
1. CONTRACTOR MAY PROPOSE ALTERNATE ARRANGEMENT OF HANDRAIL POSTS AND SUPPORTS CHANNELS TO MINIMIZE THE NUMBER OF WALKWAY PANELS TO BE FABRICATED. THE MAXIMUM HANDRAIL POST SPACING OF 6 FEET MUST NOT BE EXCEEDED. ALL CHANGES MUST BE APPROVED BY THE ENGINEER AND OWNERS PRIOR TO FABRICATION AND INSTALLATION.
 2. WHERE WALKWAY PANELS ARE FIELD CUT OR TRIMMED, PROVIDE PROTECTIVE COATING REPAIR AND/OR TOUCH-UP IN ACCORDANCE WITH THE MANUFACTURER'S RECOMMENDATIONS.
 3. PROVIDE WALKWAY SPLICE PLATES AT THE ENDS OF EACH WALKWAY PANEL IN ACCORDANCE WITH THE MANUFACTURER'S RECOMMENDATIONS.

1 AERATION BASINS AND AEROBIC DIGESTER BASINS WALKWAY PLAN
AB-6 SCALE: 1" = 10'

REVISIONS		
NO.	DATE	DESCRIPTION
1	12/21/2010	ISSUED FOR FOUNDATION PERMIT SUBMITTAL TO PPRBD (A-BASINS AND DIGESTERS)
2	01/07/2011	ISSUED FOR CONSTRUCTION PER PPRBD PERMIT #58954 (FDN ONLY)

THIS DRAWING IS THE PROPERTY OF GMS, INC., AND IS NOT TO BE RE-PRODUCED, MODIFIED OR USED FOR ANY OTHER PROJECT OR EXTENSION OF THIS PROJECT EXCEPT BY AGREEMENT WITH THIS COMPANY.

© 2010 GMS, INC.

WALKWAY PLAN
HAROLD D. THOMPSON REGIONAL WATER RECLAMATION FACILITY
LOWER FOUNTAIN METROPOLITAN SEWAGE DISPOSAL DISTRICT

DRAWN: MAL
DESIGNED: MAM
CHECKED: RJS
DATE: 2010
PROJECT NO.: 20166.362
GMS FILE NO.: 2599

GMS, INC.
CONSULTING ENGINEERS
611 N. WEBER, SUITE 300
COLORADO SPRINGS, COLORADO 80903

SHEET
AB-6
OF
—

G:\JMS\2010\166362\AB6.dwg, 17/01/2011 4:28:54 PM, gjs, DWG TO PDF, 1:1