


LEGEND

- (10') APPROXIMATE FIXTURE HEIGHT ABOVE GROUND IN FEET
- HPS WALL PACK AT MAN DOOR
- ▣ HPS WALL PACK AT OVERHEAD DOOR
- ⊠ HPS WALL PACK FOR ROAD/AREA ILLUMINATION
- ◻ HPS POLE MOUNTED LIGHT FOR ROAD/AREA ILLUMINATION
- EMPTY 2" CONDUITS, (1) AT EACH LOCATION SHOWN. INSTALL CONDUIT AT EDGE OF PAVEMENT PC UNLESS OTHERWISE NOTED. EXTEND CONDUIT A MINIMUM OF 5' BEYOND EDGE OF PAVEMENT ON EACH SIDE.



REVISIONS		
NO.	DATE	DESCRIPTION
1	11/03/2010	PRELIMINARY ISSUE FOR LIGHTING AT DIGESTERS/A-BASINS AND SECONDARY CLARIFIERS
2	05/07/2013	ISSUED FOR CONSTRUCTION

THIS DRAWING IS THE PROPERTY OF GMS, INC., AND IS NOT TO BE REPRODUCED, MODIFIED OR USED FOR ANY OTHER PROJECT OR EXTENSION OF THIS PROJECT WITHOUT THE WRITTEN AGREEMENT OF THIS COMPANY.

© 2011 GMS, INC.

SITE LIGHTING PLAN
HAROLD D. THOMPSON REGIONAL WATER RECLAMATION FACILITY
LOWER FOUNTAIN METROPOLITAN SEWAGE DISPOSAL DISTRICT

DRAWN	XXX
DESIGNED	XXX
CHECKED	XXX
DATE	2011
PROJECT NO.	20166.330
GMS FILE NO.	2599

GMS, INC.
CONSULTING ENGINEERS
611 N. WEBER, SUITE 300
COLORADO SPRINGS, COLORADO 80903

SHEET
ESP-3
OF
—

G:\PLANS\2011\166330\ESP\ESP.dwg, ESP.dwg, 5/7/2013 8:04:36 PM, rmm, DWG To PDF.pcpl, 11

FILENAME: G:\PLANS\2011\166330\ESP\ESP.dwg PLOT STYLE FILE: 10502.ctb