



**SECTION A**  
 HW-17 SCALE: 1/2" = 1'-0"

**SECTION B**  
 HW-17 SCALE: 1/2" = 1'-0"

**SECTION C**  
 HW-17 SCALE: 1/2" = 1'-0"

- SHEET NOTES:**
- \* INDICATES DIMENSIONS THAT MAY VARY ACCORDING TO MANUFACTURER'S RECOMMENDATIONS. THE CONTRACTOR SHALL VERIFY ALL DIMENSIONS WITH THE EQUIPMENT MANUFACTURERS AND APPROVED SHOP SUBMITTAL DOCUMENTS.
  - ALL ELECTRICAL EQUIPMENT AND WORK IN THE PRELIMINARY TREATMENT AREA SHALL COMPLY WITH NEC REQUIREMENTS FOR A CLASS 1, DIVISION 2, GROUP C AND D ENVIRONMENT.
  - DARKENED SIDE OF PLUG VALVE INDICATES THE SEAT SIDE OF THE VALVE.

REVISIONS		
NO.	DATE	DESCRIPTION
1	04/08/2011	ISSUED FOR PREPARATION OF CMO
2	05/17/2011	ISSUED FOR PREPARATION OF CMO
3	06/20/2011	ISSUED FOR BUILDING PERMIT SUBMITTAL TO PFRBD (HEADWORKS BUILDING)
4	08/05/2011	ISSUED FOR CONSTRUCTION PER PFRBD BUILDING PERMIT #88510 (HEADWORKS BLDG)

THIS DRAWING IS THE PROPERTY OF GMS, INC., AND IS NOT TO BE REPRODUCED, MODIFIED OR USED FOR ANY OTHER PROJECT OR EXTENSION OF THIS PROJECT EXCEPT BY AGREEMENT WITH THIS COMPANY.

**PROCESS EQUIPMENT AND PIPING SECTIONS**  
 HAROLD D. THOMPSON REGIONAL WATER RECLAMATION FACILITY  
 LOWER FOUNTAIN METROPOLITAN SEWAGE DISPOSAL DISTRICT

DRAWN	SKC	GMS, INC. CONSULTING ENGINEERS 611 N. WEBER, SUITE 300 COLORADO SPRINGS, COLORADO 80903	SHEET <b>HW-17</b> OF -
CHECKED	RJS		
DATE	2010		
PROJECT NO.	20166.352		
GMS FILE NO.	2599		

XREF FILENAME: G:\  
 BASE DWG: G:\  
 PLOT STYLE FILE: 1000C17H  
 FILENAME: G:\PMSD0\20166\_352\HW17\HW17.DWG

G:\PMSD0\20166\_352\HW17\HW17.dwg, HW17, 8/20/11 10:28:03 AM, CL, DWG TO PDF, PLOT, 11