

STRUCTURAL GENERAL NOTES:

DESIGN CRITERIA

1. DESIGN LIVE LOADS ARE IN ACCORDANCE WITH THE INTERNATIONAL BUILDING CODE, 2009 EDITION, WITH THE FOLLOWING MINIMUM CRITERIA:

FLOOR LOADS:		CONCENTRATED
OCCUPANCY OR USE:	LIVE LOAD:	LOAD:
FLOORS (UNLESS NOTED OTHERWISE).....	150 p.s.f.	4000 lbs.
VEHICLE BAY FLOOR – HS20–44 TRUCK.....	640 p.s.f.	18 kips(FOR MOMENT) 26 kips(FOR SHEAR)

SNOW LOADS:

ROOF DESIGN SNOW LOAD, Pf (NON–REDUCIBLE)	30 p.s.f.
EXPOSURE FACTOR, Ce	1.0
IMPORTANCE FACTOR, Is	1.1
THERMAL FACTOR, Ct	1.0
GROUND SNOW LOAD, Pg	30 p.s.f.

SEISMIC LOADS:

IMPORTANCE FACTOR, Ie	1.25
-----------------------------	------

MAPPED SPECTRAL RESPONSE ACCELERATIONS:

Ss.....	0.185
S1.....	0.059
.....	D

SITE CLASS

SPECTRAL RESPONSE COEFFICIENTS:

Sps.....	0.197
Sd1.....	0.094

SEISMIC DESIGN CATEGORY

BASIC SEISMIC–FORCE–RESISTING SYSTEMS:
ORDINARY STEEL MOMIENT FRAME

DESIGN BASE SHEAR: BY PRE ENGINEERED METAL BUILDING MANUFACTURE
RESPONSE MODIFICATION FACTOR, R: 3.5

ANALYSIS PROCEDURE: EQUIVALENT LATERAL FORCE PROCEDURE

WIND LOADS:

BASIC WIND SPEED (3–SECOND GUST):	100 m.p.h.
WIND EXPOSURE	C
IMPORTANCE FACTOR, Iw	1.15
INTERNAL PRESSURE COEFFICIENT, GCpi	±0.18

FLOOD LOADS:

NOT IN FLOOD HAZARD ZONE

2. THE GENERAL CONTRACTOR SHALL BE RESPONSIBLE TO COORDINATE THE LOCATION OF MECHANICAL OPENINGS, FLOOR DRAINS, INSERTS, DEPRESSIONS, BURIED CABLES AND UTILITIES, ETC. WITH ARCHITECTURAL, CIVIL, MECHANICAL AND ELECTRICAL DRAWINGS.
3. VERIFY ALL DIMENSIONS WITH ARCHITECTURAL DRAWINGS. NOTIFY ENGINEER OF DISCREPANCIES. WRITTEN DIMENSIONS TAKE PRECEDENCE OVER SCALED DIMENSIONS.

SOILS AND FOUNDATIONS

1. FOUNDATION DESIGN IS IN ACCORDANCE WITH THE SOIL REPORT BY HEPWORTH–PAWLAK GEOTECHNICAL, INC, NUMBER 308121B, DATED MARCH 4, 2009.

2. DESIGN OF DRILLED PIERS IS BASED ON THE FOLLOWING CRITERIA:

MAXIMUM ALLOWABLE END BEARING PRESSURE	30,000 p.s.f.
MINIMUM ALLOWABLE END BEARING PRESSURE	15,000 p.s.f.
MAXIMUM ALLOWABLE SKIN FRICTION	2,500 p.s.f.
MINIMUM PENETRATION INTO BEDROCK	8.0 feet
MINIMUM DRILLED PIER LENGTH	20.0 feet

THE MAXIMUM VARIATION OF THE CENTER OF ANY DRILLED PIER AT ITS TOP FROM THE REQUIRED LOCATION SHALL NOT BE MORE THAN 5–1/2% OF ITS DIAMETER AND NO PIER SHALL BE OUT OF PLUMB MORE THAN 1% OF ITS LENGTH.

3. SOIL BENEATH SLABS ON GRADE SHALL BE NATIVE, SOLID UNDISTURBED MATERIAL FREE OF WATER, FROST OR FOREIGN DEBRIS, OR STRUCTURAL FILL COMPACTED IN ACCORDANCE WITH THE SOILS REPORT AND SPECIFICATIONS WITH MINIMUM DENSITY AS FOLLOWS:

SLABS–ON–GRADE: 95% OF STANDARD PROCTOR, ASTM D698.

4. A REPRESENTATIVE OF THE SOILS ENGINEER SHALL INSPECT THE OPEN EXCAVATION TO DETERMINE THAT THE SOIL TYPE AND CONDITIONS ARE CONSISTENT WITH DESIGN CRITERIA OF THE SOILS REPORT. IF THE SOIL PROPERTIES ARE FOUND TO BE DIFFERENT FROM THIS CRITERIA, THEN THE ENGINEER SHALL BE PROMPTLY NOTIFIED SO THAT THE FOUNDATION DESIGN MAY BE REVIEWED.

CONCRETE:

1. ALL CONCRETE DESIGN, MATERIALS AND CONSTRUCTION SHALL CONFORM TO ACI STANDARD 318–08, THE INTERNATIONAL BUILDING CODE, 2009 EDITION, THE CRSI MANUAL OF STANDARD PRACTICE (CURRENT EDITION) AND THE PROJECT SPECIFICATIONS.

2. MATERIAL SPECIFICATIONS:

REINFORCING BARS	ASTM A615, GR. 60
WELDED WIRE FABRIC	ASTM A185
REINFORCING BARS (WELDED)	ASTM A706, GR. 60

3. CONCRETE SHALL HAVE A MINIMUM COMPRESSIVE STRENGTH IN 28 DAYS AS FOLLOWS:

A. GENERAL STRUCTURAL CONCRETE

GRADE BEAMS & WALLS	4500 p.s.i.	CEMENT TYPE 1/II
FLOOR SLABS	4500 p.s.i.	CEMENT TYPE 1/II
SLABS–ON–GRADE	4500 p.s.i.	CEMENT TYPE 1/II
(WITH 1.5 lbs OF FIBERMESH PER CUBIC YARD)		
EQUIPMENT PEDESTALS	4500 p.s.i.	CEMENT TYPE 1/II
DRILLED PIERS (5"–7" SLUMP)	3750 p.s.i.	CEMENT TYPE 1/II

4. REINFORCEMENT SHALL BE DETAILED IN ACCORDANCE WITH THE ACI DETAILING MANUAL, LATEST EDITION. FORMWORK SHALL BE DESIGNED, ERECTED AND REMOVED IN ACCORDANCE WITH THE SPECIFICATIONS.
5. REINFORCEMENT SHALL BE PLACED SO THAT THE FOLLOWING MINIMUM CONCRETE PROTECTION IS PROVIDED, UNLESS NOTED OTHERWISE.

CONCRETE SURFACES POURED AGAINST GROUND 3" CLEAR

FORMED SURFACES EXPOSED TO GROUND OR WEATHER

 BARS #6 AND LARGER 2" CLEAR

 BARS #5 AND SMALLER..... 1–1/2" CLEAR

 SLABS–ON–GRADE AT CENTERS

6. REINFORCEMENT SHALL BE SECURELY TIED AND SHALL BE SUPPORTED WITH METAL CHAIRS OR HUNG FROM FORMS.
7. CONTINUOUS HORIZONTAL BARS AND CORNER BARS IN GRADE BEAMS AND SLABS SHALL BE LAPPED AS FOLLOWS AT SPLICES. SPLICE LOCATIONS SHALL BE STAGGERED WHERE POSSIBLE.

CONCRETE COMPRESSIVE STRENGTH	No. 6 BARS & SMALLER	No. 7 BARS & LARGER
4500 p.s.i	38 db	48 db
(WHERE db = BAR DIAMETERS)		

SPLICES IN GRADE BEAM REINFORCING IF REQUIRED SHALL BE AS FOLLOWS:

 BOTTOM BARS AT DRILLED PIERS

 TOP BARS MID SPAN BETWEEN DRILLED PIERS

8. ADDITIONAL (2) #6 BARS (ONE EACH FACE) WITH A 2'–0" PROJECTION SHALL BE PLACED DIAGONALLY ACROSS THE CORNERS OF ALL OPENINGS AND VERTICAL STEPS IN WALLS.
9. GRADE BEAMS BELOW GRADE SHALL HAVE BACKFILL PLACED EQUALLY ON BOTH SIDES UNTIL THE REQUIRED LEVELS ARE REACHED.

2

10. CONSTRUCTION JOINTS IN SLABS ON GRADE SHALL BE SPACED AT INTERVALS ENCLOSING NO MORE THAN 144 SQUARE FEET WITH A MAXIMUM OF 12 FEET IN ANY ONE DIRECTION UNLESS OTHERWISE NOTED ON DRAWINGS. CONSTRUCTION JOINTS SHALL BE FORMED WITH METAL LOAD KEY JOINT SUPPLIED BY JAHN CONCRETE PRODUCTS OR APPROVED EQUAL. FOR CONSTRUCTION JOINTS IN SLABS 6" AND THICKER PROVIDE 1 INCH DIAMETER X 24" LONG SMOOTH DOWELS AT 18" ON CENTER OILED ONE END. REFER TO PROJECT MANUAL FOR SEALING OF CONSTRUCTION JOINTS.

2

11. CONSTRUCTION JOINTS (COLD JOINTS) SHALL BE PROVIDED IN GRADE BEAMS, WHICH ARE OVER 70 FEET IN A STRAIGHT RUN. KEYWAYS SHALL BE PROVIDED AT ALL CONSTRUCTION JOINTS IN GRADE BEAMS.

2

12. CONTROL JOINTS IN SLABS MAY BE TOOLED OR SAWCUT AS INDICATED ON THE DRAWINGS.

2

13. ALL JOINTS SHALL BE APPROVED BY THE ENGINEER.

STRUCTURAL STEEL:

1. ALL STRUCTURAL STEEL DESIGN, MATERIALS, FABRICATION AND ERECTION SHALL CONFORM TO THE AISC SPECIFICATION, 3TH EDITION, THE INTERNATIONAL BUILDING CODE, 2009 EDITION AND THE PROJECT SPECIFICATIONS.
2. MATERIAL SPECIFICATIONS:

REVISIONS

NO.	DATE	DESCRIPTION
1	01/28/2011	ISSUED FOR FOUNDATION PERMIT SUBMITTAL TO PPRBD (HEADWORKS BUILDING)
2	05/17/2011	ISSUED FOR PREPARATION OF CMO
3	06/20/2011	ISSUED FOR BUILDING PERMIT SUBMITTAL TO PPRBD (HEADWORKS BUILDING)
4	08/05/2011	ISSUED FOR CONSTRUCTION PER PPRBD BUILDING PERMIT #68510 (HEADWORKS BLDG)

THIS DRAWING IS THE
PROPERTY OF GMS, INC.,
AND IS NOT TO BE RE–
PRODUCED, MODIFIED OR
USED FOR ANY OTHER
PROJECT OR EXTENSION
OF THIS PROJECT EXCEPT
BY AGREEMENT WITH THIS
COMPANY.

GMS, INC.

STRUCTURAL GENERAL NOTES
HAROLD D. THOMPSON REGIONAL WATER RECLAMATION FACILITY
LOWER FOUNTAIN METROPOLITAN SEWAGE DISPOSAL DISTRICT

DRAWN SKC
DESIGNED JP/MG
CHECKED MG
DATE MARCH 2010
PROJECT NO. 20166.352
GMS FILE NO. 2599

GMS, INC.
CONSULTING ENGINEERS
611 N. WEBER, SUITE 300
COLORADO SPRINGS, COLORADO 80903

SHEET
1–4
OF
—

XREF FILENAME: G:\
BASE.DWG: G:\
PLOT STYLE FILE: 100SC.DTG
FILENAME: G:\FMSDD\20166\INFORMATIONAL DRAWINGS\4\4.DWG