

MANHOLE/STRUCTURE COATING SCHEDULE @ HDTWRWF
1/19/2012 ddf

Status	Sheet No.	STRUCTURE	EXTERIOR COATING	INTERIOR LINING	STRUCTURE COVER	COMMENTS
IFC 12-14-11	G-19	Wye Structure	None Required	Sherflex	I-Bar Grating	Coat interior to full depth
IFC 12-14-11	G-38	MH-01	External joint wrap only	Sherflex	Composite Ring & Cover	Coat interior to full depth
IFC 03-20-12	G-23	Flow Diversion Structure	None Required	Sherflex	I-Bar Grating	Coat interior to full depth
IFC 03-12-12	G-20	MH-02 w/ grate	External joint wrap only	Sherflex	I-Bar Grating	Coat interior to full depth
IFC 03-12-12	G-20	MH-03 w/ grate	External joint wrap only	Sherflex	I-Bar Grating	Coat interior to full depth
IFC 03-02-12	G-22	AB Splitter Structure	None Required	Coal-Tar Epoxy	I-Bar Grating	Coat "band" area per elevations shown on the drawings
IFC 03-02-12	G-27	AB Level Control Structure	None Required	Coal-Tar Epoxy	I-Bar Grating	Coat "band" area per elevations shown on the drawings
IFC 03-02-12	G-25	MH-04	External joint wrap only	Coal-Tar Epoxy	I-Bar Grating	Coat "band" area per elevations shown on the drawings
IFC 03-02-12	G-25	MH-05	External joint wrap only	Coal-Tar Epoxy	I-Bar Grating	Coat "band" area per elevations shown on the drawings
IFC 03-02-12	G-26	Clarifier Splitter Structure	None Required	Coal-Tar Epoxy	I-Bar Grating	Coat "band" area per elevations shown on the drawings
IFC 06-10-11	SC-7,SC-11	MH-06	External joint wrap only	None Required	Aluminum Ring & Cover	upstream of UV
Issued 04-04-11	G-28	MH-07 to MH-09	Damp-proof coating +Jt Wrap	None Required	Cast Iron Ring & Cover	downstream of UV
IFC 03-08-12	G-31	MH-12	External joint wrap only	Coal-Tar Epoxy	Composite Ring & Cover	Coat interior to full depth
IFC 03-09-12	G-39	MH-12A	External joint wrap only	Coal-Tar Epoxy	Composite Ring & Cover	Coat interior to full depth
IFC 03-08-12	G-31	MH-13	External joint wrap only	Coal-Tar Epoxy	Composite Ring & Cover	Coat interior to full depth
IFC 03-08-12	G-31	MH-13A	External joint wrap only	Coal-Tar Epoxy	Composite Ring & Cover	Coat interior to full depth
IFC 06-10-11	SC-7,SC-10	Valve Access Manholes	External joint wrap only	None Required	Alum. Checker Plate Hatch	

updates:

02-14-12 mam
02-22-12 mam
03-02-12 mam
03-08-12 mam
03-09-12 ddf
03-12-12 mam
03-20-12 mam