



- SHEET NOTES:**
- * INDICATES VERIFICATION REQUIRED. PRIOR TO CONSTRUCTION, VERIFY ALL DIMENSIONS AND ELEVATIONS RELATIVE TO THE ACTUAL PUMPS AND EQUIPMENT PROVIDED TO ENSURE PROPER ALIGNMENTS AND INSTALLATION CONDITIONS.
 - ALL FLOOR TYPE PIPE SUPPORTS SHALL BE PROVIDED AS HOT DIP GALVANIZED OR PAINTED STEEL.
 - CONTRACTOR MAY MAKE MINOR ADJUSTMENTS TO THE LOCATIONS OF THE PIPE SUPPORTS SHOWN TO ACCOMMODATE INSTALLATION CONDITIONS.
 - SEE PIPING PLAN FOR PIPE COLOR LEGEND.

NO.	DATE	DESCRIPTION
1	12/02/2011	ISSUED FOR VALUE ENGINEERING COMMENTS
2	01/06/2012	ISSUED FOR VALUE ENGINEERING
3	01/25/2012	ISSUED FOR PD BUILDING VALUE ENGINEERING REVIEW AND COMMENTS
4	04/16/2012	ISSUED FOR BUILDING PERMIT SUBMITTAL TO PHRD (PUMPING AND DISINFECTION BLDG)
5	05/21/2012	ISSUED FOR CONSTRUCTION PER PERMITS BLDG PERMITS #8893 (PUMP AND DISINFECTION BLDG)

THIS DRAWING IS THE PROPERTY OF GMS, INC., AND IS NOT TO BE REPRODUCED, MODIFIED OR USED FOR ANY OTHER PROJECT OR EXTENSION OF THIS PROJECT EXCEPT BY AGREEMENT WITH THIS COMPANY.

PROCESS PIPING SECTIONS
HAROLD D. THOMPSON REGIONAL WATER RECLAMATION FACILITY
LOWER FOUNTAIN METROPOLITAN SEWAGE DISPOSAL DISTRICT

DRAWN	SKC
DESIGNED	MAM
CHECKED	RJS
DATE	2011
PROJECT NO.	20166.372
GMS FILE NO.	2599

GMS, INC.
CONSULTING ENGINEERS
611 N. WEBER, SUITE 300
COLORADO SPRINGS, COLORADO 80903

SHEET
PD-15
OF

G:\INSTRUC\2011\05\27\PD15.dwg, PDS, 5/27/2012, 3:38:19 PM, ac, DWG To PDF, p11