

6. ALL JOINTS SHALL HAVE SEALANT INSTALLED ON EXPOSED SIDES OF JOINT.

SHEET HW-12.

7. ALL KEYED WALL JOINTS SHALL BE CONSTRUCTED ACCORDING TO THE SHEAR KEY DETAIL GIVEN ON

8. ALL WALL JOINTS SHALL BE MINIMUM 2 FEET FROM ANY SLAB JOINT AND MINIMUM 5 FEET FROM ANY DRILLED PIER UNLESS OTHERWISE SHOWN.

XREF FILENAME: G:\ BASE DWG: G:\ PLOT STYLE FILE: 1050C.CTB FILENAME: G:\LFMSDD\20166\372\PD5A\PD5A.DWG

1 09/22/2011 ISSUED FOR FOUNDATION PERMIT SUBMITTAL TO PPRBD (PUMPING AND DISINFECTION BLDG 2 10/17/2011 ISSUED FOR CONSTRUCTION PER PPRBD FOUNDATION PERMIT #98993 (PUMP AND DISINFECTION BLDG)
3 01/06/2012 ISSUED FOR VALUE ENGINEERING
4 01/25/2012 ISSUED FOR PD BUILDING VALUE ENGINEERING REVIEW AND COMMENTS 5 04/18/2012 ISSUED FOR BUILDING PERMIT SUBMITTAL TO PPRBD (PUMPING AND DISINFECTION BL 6 05/21/2012 ISSUED FOR CONSTRUCTION PER PPRBD BLDG PERMIT #98993 (PUMP AND DISINFECTION BLD

PROPERTY OF GMS, INC., AND IS NOT TO BE RE— PRODUCED, MODIFIED OR USED FOR ANY OTHER PROJECT OR EXTENSION

OF THIS PROJECT EXCEPT BY AGREEMENT WITH THIS

© 2011 GMS, INC.

COMPANY.

## JOINTING PLAN

HAROLD D. THOMPSON REGIONAL WATER RECLAMATION FACILITY LOWER FOUNTAIN METROPOLITAN SEWAGE DISPOSAL DISTRICT

DRAWN	SKC/MAM	
DESIGNED N	MAM/RJS	
CHECKED	RJS	
DATE	2011	
PROJECT NO	20166.372	
GMS FILE NO.	2599	

GMS, INC. CONSULTING ENGINEERS 611 N. WEBER, SUITE 300 COLORADO SPRINGS, COLORADO 80903

