



REVISIONS

NO.	DATE	DESCRIPTION
1	03/25/2011	ISSUED FOR BUILDING PERMIT SUBMITTAL TO PERMITS (SECONDARY CLARIFIER COMPLEX)
2	06/15/2011	ISSUED FOR CONSTRUCTION (SECONDARY CLARIFIER COMPLEX)
3	07/07/2011	ESP. NO. 009

PROCESS PIPING PLAN

HAROLD D. THOMPSON REGIONAL WATER RECLAMATION FACILITY
LOWER FOUNTAIN METROPOLITAN SEWAGE DISPOSAL DISTRICT

PROPERTY OF GMS, INC., AND IS NOT TO BE REPRODUCED, MODIFIED OR COPIED IN ANY MANNER WITHOUT THE WRITTEN CONSENT OF GMS, INC. THIS PROJECT EXCEPT BY AGREEMENT WITH THIS COMPANY.

DESIGNED: RJS
 CHECKED: RJS
 DATE: 2010
 PROJECT NO.: 2010B.362
 GMS FILE NO.: 2599

SECONDARY CLARIFIER PIPING PLAN

SCALE: 1" = 5'

SHEET NOTES:

- FOR 6" PIPE WITH JOINT RESTRAINTS, RESTRAIN ALL PIPE AND JOINTS ON EACH SIDE OF EACH BEND OR FITTING FOR A MINIMUM LENGTH OF 4 FEET.
- FOR 10" PIPE WITH JOINT RESTRAINTS, RESTRAIN ALL PIPE AND JOINTS ON EACH SIDE OF EACH BEND OR FITTING FOR A MINIMUM LENGTH OF 5 FEET.
- FOR 12" PIPE WITH JOINT RESTRAINTS, RESTRAIN ALL PIPE AND JOINTS ON EACH SIDE OF EACH BEND OR FITTING FOR A MINIMUM LENGTH OF 6 FEET.
- FOR 16" PIPE WITH JOINT RESTRAINTS, RESTRAIN ALL PIPE AND JOINTS ON EACH SIDE OF EACH BEND OR FITTING FOR A MINIMUM LENGTH OF 8 FEET.