### **SECTION 09700**

#### FLOOR SEALER

### PART 1 - GENERAL

## 1.1 DESCRIPTION

# A. Scope

- 1. Furnish and apply clear floor sealer to all concrete floors subject to foot traffic and which are not required to be covered with flooring materials
- B. Additional Requirements Specified Elsewhere
  - 1. Section 01340: Shop Drawings, Product Data, and Samples
  - 2. Section 01600: Materials and Equipment
- C. Related Requirements Specified Elsewhere
  - 1. Section 03300: Cast-in-Place Concrete
  - 2. Section 09650: Resilient Flooring

### 1.2 QUALITY ASSURANCE

- A. Design Basis
  - 1. Dayton Superior "Cure & Seal"
  - 2. Protex "Acrychlor"
  - 3. Sonneborn "Kure-N-Seal"
  - 4. Or equivalent
  - 5. Equivalent products of other manufacturers may be accepted subject to compliance with design, function, materials, and performance of the specified items

### 1.3 SUBMITTALS

A. Furnish complete manufacturer's product data, certificates, and test data in accordance with Section 01340

# 1.4 DELIVERY, STORAGE, AND HANDLING

A. Deliver in manufacturer's unopened containers and store at a temperature of at least 50°F

# PART 2 - PRODUCTS

### 2.1 MATERIALS

### A. Floor Sealer

- 1. Fast drying, water-clear, chemically neutral compound
- 2. Non-yellowing
- 3. Fed Spec TT-C-800, Type I, and ASTM C309
- 4. Minimum 18% solids
- 5. Minimum water retention: 0.039 gm/cm<sup>2</sup>

### PART 3 - EXECUTION

## 3.1 INSTALLATION

- A. Apply to all concrete floors subject to foot traffic and which are not required to be covered with flooring materials
- B. Two (2) coats of clear floor sealer in addition to any coats which may have been applied as membrane curing compound
- C. Prior to application of each coat, thoroughly clean the floor of all dirt, grease, oil, and other foreign matter
  - 1. All concrete surfaces to receive floor sealer shall be dry and clean
- D. Apply first coat at end of curing period and before any traffic is permitted on the floor
- E. Apply second coat after floor has been cleaned, in preparation for final inspection of the Work
- F. Apply in strict accordance with manufacturer's recommendations

**END OF SECTION**