


REQUEST FOR INFORMATION

Request for Information -	003	ROUTING	DATE SENT	VIA MAIL, EMAIL OR FAX			DATE RECEIVED	VIA MAIL, EMAIL OR FAX		
				M	E	F		M	E	F
OWNER: LFMSDD		Contractor to Engineer	1/17/2011		X		1/17/2011		X	
PROJECT: HDTRWRF		Engineer to Contractor	1/17/2011		X					
ENGINEER: GMS, Inc.		Copy to Owner	1/17/2011		X					
CONTRACTOR: Weaver General Construction Co.										
RFI TITLE: Mat Construction Joint Detail										
REFERENCE: Drawing 3/AB-4										
CONTRACTOR'S REQUEST										
The following information, interpretation, or clarification is requested as described below or in the attachments.										
Detail 3 on AB-4 calls for the mat construction joint keyway to be inverted. Baker Concrete proposes to build the mat construction joints per the attached detail. Is this acceptable?										
By: John Jacob Date: 1/17/11										
ENGINEER'S RESPONSE										
The following information, interpretation, or clarification is provided as described below or in the attachments.										
We take no exception to the mat construction joint keyway provided by Baker Concrete.										
By: David R. Frisch, P.L.S. Date: January 17, 2011										

cc: Wes Weaver, Jeff Burst, John Jacob, WGCC; Jim Heckman, LFMSDD; Tim Long, Charlie Edgar, Cindy Murray, FSD; Al Testa, CCMD; Roger Sams, Dave Frisch, Jerry Miller, GMS, Inc.; Pat Danenberg, MWI; John Peiffer, Mike Gaines, MGA; Mark Reasinger, PECI



1 MAT SLAB CONSTRUCTION JOINT DETAIL
Scale: 1/2"=1'-0"

THESE DRAWINGS ARE INTENDED FOR USE BY
BAKER CONCRETE CONSTRUCTION, INC. (BCCI)
ONLY. BCCI DOES NOT ASSUME OR ACCEPT ANY
LIABILITY FOR THEIR USE BY ANYONE OTHER
THAN BCCI.

USE THIS DRAWING IN CONJUNCTION WITH THE
STRUCTURAL CONSTRUCTION DOCUMENTS AND
DRAWINGS.

SK-02

BAKER
CONCRETE CONSTRUCTION

8300 Hempstead Rd. Houston, Tx. 77008
Phone: 713.864.0657 | Fax: 713.880.0222
www.bakerconcrete.com

Texas Firm # F-11611

HAROLD THOMPSON WRF

REV.	DATE	DESCRIPTION	BY:
0	1/12/11	KEYWAY DETAILS	LFC

DRAWN BY : LFC
DATE : 1.12.11
CHECKED BY :
DATE :
JOB # : 9921
SCALE : 1/2"=1'-0"