

**GMS, INC.**  
CONSULTING ENGINEERS  
611 NORTH WEBER, SUITE 300  
COLORADO SPRINGS, COLORADO 80903-1074

TELEPHONE (719) 475-2935  
TELEFAX (719) 475-2938

EDWARD D. MEYER, P.E.  
ROGER J. SAMS, P.E.  
GREGORY R. WORDEN, P.E.  
THOMAS A. McCLERNAN, P.E.

KEN L. WHITE, P.L.S.  
DAVID R. FRISCH, P.L.S.  
MARK A. MORTON, P.E.  
JASON D. MEYER, P.E.

September 5, 2012

Mr. Wes Weaver, President  
Weaver Construction Management, Inc.  
3679 South Huron Street, Suite 404  
Englewood, CO 80110

*Via Email to: wes@weavercm.com  
No Hard Copy to Follow*

Re: Harold D. Thompson Regional Water Reclamation Facility (HDTRWRF)  
Lower Fountain Metropolitan Sewage Disposal District (LFMSDD)

Dear Wes:

Reference is made to your shop submittal identified as follows:

Submittal No.:	11211-001B
Date of Submittal:	September 12, 2011
Title:	NPW System-Above Grade Packaged Pump Station (NPP-1, NPP-2, NPP-3, NPP-4) – Response to Comment 2.C. Line Reactors
Specification Section:	11211 – Packaged Pump Station
Manufacturers:	Usemco Incorporated; Tnemec Company, Inc.; Valspar; Grundfos; Nibco, Inc.; Val-Matic Valve & Manufacturing Corp.; Cla-Val; Wessels Company; Ashcroft; Hoffman Enclosures Inc.; Schneider Electric/Square D; Yasakawa America, Inc.; Sola; atc Diversified Electronics; IDEC; Allen-Bradley; Setra

The referenced submittal has been stamped "**No Exception Taken**". Our comments are as follows:

1. We take no exception to the MTE line reactor with NEMA 4 enclosure submitted.
2. We trust that Comment No. 2 of the previous review submittal regarding the change from 4-wire electrical supply to a 3-wire electrical supply has been accounted for.

Please call if you should have any questions.

Sincerely,



Mark A. Morton, P.E.

MAM/kmw

ec (letter only):

Mr. Jim Heckman, Manager, LFMSDD, [lfmanager@lfmsdd.org](mailto:lfmanager@lfmsdd.org)  
Ms. Cindy Murray, Office Manager, Fountain Sanitation District, [fsdistrict@fsd901.org](mailto:fsdistrict@fsd901.org)  
Mr. Jeff Burst, Project Supt., Weaver Construction Management, Inc., [jeff@weavercm.com](mailto:jeff@weavercm.com)  
Mr. John Jacob, Project Mgr., Weaver Construction Management, Inc., [john@weavercm.com](mailto:john@weavercm.com)  
Mr. Adam Roeder, Weaver Construction Management, Inc., [aroeder@weavercm.com](mailto:aroeder@weavercm.com)  
Ms. Leslie Brown, Weaver Construction Management, Inc., [leslie@weavercm.com](mailto:leslie@weavercm.com)  
Mr. Mark Reasinger, P.E., Plant Engineering Consultants, Inc., [mreasinger@planteci.com](mailto:mreasinger@planteci.com)  
cc: Mr. Jerry Miller, Resident Project Representative, GMS, Inc. (w/Submittals 11211-001A & 001B)