

GMS, INC.
CONSULTING ENGINEERS
611 NORTH WEBER, SUITE 300
COLORADO SPRINGS, COLORADO 80903-1074

TELEPHONE (719) 475-2935
TELEFAX (719) 475-2938

EDWARD D. MEYER, P.E.
ROGER J. SAMS, P.E.
GREGORY R. WORDEN, P.E.
THOMAS A. McCLERNAN, P.E.

KEN L. WHITE, P.L.S.
DAVID R. FRISCH, P.L.S.
MARK A. MORTON, P.E.
JASON D. MEYER, P.E.

December 23, 2011

Mr. Wes Weaver, President
Weaver Construction Management, Inc.
3679 South Huron Street, Suite 404
Englewood, CO 80110

Via Email to: wes@weavergc.com
No Hard Copy to Follow

Re: Harold D. Thompson Regional Water Reclamation Facility (HDTRWRF)
Lower Fountain Metropolitan Sewage Disposal District (LFMSDD)

Dear Wes:

Reference is made to your shop submittal identified as follows:

Submittal No.:	11280-002
Date of Submittal:	December 19, 2011
Title:	SS Slide Gates for Pumping and Disinfection Building-SG-7 to SG-10
Specification Section:	11280-Slide Gates
Manufacturer:	Whipps, Inc.

The referenced submittal has been stamped "**Make Corrections Noted**". Our comments are as follows:

1. We take no exception to the Whipps, Inc. stainless steel slide gate proposed for use in the Pumping and Disinfection Building.
2. The drawing titled, SERIES 921 STAINLESS GATE INSTALL. 36" x 54", shows an operator elevation of the handwheel at 5424.83. Per Addendum No. Seven (7) issued for the project, the operator level is to be at 5408.20. We request the correction be made to the drawing.
3. The drawing titled, SERIES 921 STALL STEEL GATE INSTALL. 25" x 54", shows an operator elevation of the handwheel at 5424.83. Per Addendum No. Seven (7) issued for the project, the operator level is to be at 5408.20. We request the correction be made to the drawing.

Please call if you should have any questions.

Sincerely,



David R. Frisch, P.L.S.

DRF/kmw

ec (letter only):

Mr. Jim Heckman, Manager, LFMSDD, lfmanager@lfmsdd.org
Ms. Cindy Murray, Office Manager, Fountain Sanitation District, fsdistrict@fsd901.org
Mr. Jeff Burst, Project Supt., Weaver Construction Management, Inc., jeff@weavergc.com
Mr. John Jacob, Project Mgr., Weaver Construction Management, Inc., john@weavergc.com
Mr. Tyler Ammerman, Weaver Construction Management, Inc., tammerman@weavergc.com
Ms. Leslie Brown, Weaver Construction Management, Inc., leslie@weavergc.com

cc: Mr. Jerry Miller, Resident Project Representative, GMS, Inc.