

**GMS, INC.**  
CONSULTING ENGINEERS  
611 NORTH WEBER, SUITE 300  
COLORADO SPRINGS, COLORADO 80903-1074

TELEPHONE (719) 475-2935  
TELEFAX (719) 475-2938

EDWARD D. MEYER, P.E.  
ROGER J. SAMS, P.E.  
GREGORY R. WORDEN, P.E.  
THOMAS A. McCLERNAN, P.E.

KEN L. WHITE, P.L.S.  
DAVID R. FRISCH, P.L.S.  
MARK A. MORTON, P.E.  
JASON D. MEYER, P.E.

October 26, 2011

Mr. Wes Weaver, President  
Weaver Construction Management, Inc.  
3679 South Huron Street, Suite 404  
Englewood, CO 80110

*Via Email to: wes@weavergc.com*  
*No Hard Copy to Follow*

Re: Harold D. Thompson Regional Water Reclamation Facility (HDTRWRF)  
Lower Fountain Metropolitan Sewage Disposal District (LFMSDD)

Dear Wes:

Reference is made to your shop submittal identified as follows:

Submittal No.:	11322-001A
Date of Submittal:	September 29, 2011
Title:	Vortex Grit Chambers: Motor Data, Mechanical Components, Controls and General Electrical Shop Drawings
Specification Section:	11322-Vortex Grit Chambers
Manufacturers:	US Motors/Nidec Motor Corporation; Emerson Motor Technologies; Nord Gear; Sprecher+Schuh; Omron; Turck Industrial Automation; Redington; Schloss Engineered Equipment, Inc.

The referenced submittal has been stamped "**No Exception Taken**". Our comments are as follows:

1. Schloss Engineered Equipment, Inc. has satisfactorily responded to the comments directed to them for the vortex grit chambers.
2. Several comments in the initial shop submittal response letter were not specifically addressed by the General Contractor. Lack of response by the General Contractor does not alleviate the contractor from their responsibilities during the construction phase to ensure those items noted have been addressed including:
  - The anchor bolts will be provided by the General Contractor in lieu of the equipment supplier and will meet the needs and requirements of the submitted equipment.
  - The prime paint provided on the equipment to be delivered to the project site will be compatible with the field finish paint by others.
3. The equipment supplier has indicated major control component cut sheets were provided in the prior shop submittal which we acknowledge. Numerous other control components were not included in the shop submittal. An indication of **No Exception Taken** to this shop submittal does not alleviate the Contractor from being fully responsible for providing all required control parts, pieces and components necessary for the equipment identified in Specification Sections

Mr. Wes Weaver  
October 26, 2011  
Page 2

11314, 11321 and 11322. By taking no exception to this shop submittal, it is understood the General Contractor will ensure all control parts, pieces and components will be provided and installed in accordance with the project specifications and Construction Drawings.

Please call if you should have any questions.

Sincerely,



David R. Frisch, P.L.S.

DRF/kmw

ec (letter only):

Mr. Jim Heckman, Manager, LFMSDD, [lfmanager@lfmsdd.org](mailto:lfmanager@lfmsdd.org)

Ms. Cindy Murray, Office Manager, Fountain Sanitation District, [fsdistrict@fsd901.org](mailto:fsdistrict@fsd901.org)

Mr. Jeff Burst, Project Supt., Weaver Construction Management, Inc., [jeff@weavergc.com](mailto:jeff@weavergc.com)

Mr. John Jacob, Project Mgr., Weaver Construction Management, Inc., [john@weavergc.com](mailto:john@weavergc.com)

Mr. Tyler Ammerman, Weaver Construction Management, Inc., [tammerman@weavergc.com](mailto:tammerman@weavergc.com)

Ms. Leslie Brown, Weaver Construction Management, Inc., [leslie@weavergc.com](mailto:leslie@weavergc.com)

cc: Mr. Jerry Miller, Resident Project Representative, GMS, Inc.