

GMS, INC.
CONSULTING ENGINEERS
611 NORTH WEBER, SUITE 300
COLORADO SPRINGS, COLORADO 80903-1074

TELEPHONE (719) 475-2935
TELEFAX (719) 475-2938

EDWARD D. MEYER, P.E.
ROGER J. SAMS, P.E.
GREGORY R. WORDEN, P.E.
THOMAS A. McCLENNAN, P.E.

KEN L. WHITE, P.L.S.
DAVID R. FRISCH, P.L.S.
MARK A. MORTON, P.E.
JASON D. MEYER, P.E.

December 13, 2012

Mr. Wes Weaver, President
Weaver Construction Management, Inc.
3679 South Huron Street, Suite 404
Englewood, CO 80110

Via Email to: wes@weavercm.com
No Hard Copy to Follow

Re: Harold D. Thompson Regional Water Reclamation Facility (HDTRWRF)
Lower Fountain Metropolitan Sewage Disposal District (LFMSDD)

Dear Wes:

Reference is made to your shop submittal identified as follows:

Submittal No.:	12346-001B
Date of Submittal:	December 5, 2012
Title:	Casework, Color Chart, Fume Hood
Specification Section:	12346 – Laboratory Casework
Manufacturer:	Thermo Fisher Scientific; Haldeman-Homme, Inc.; Fisher Hamilton; WaterSaver Faucet Co.

The referenced submittal has been stamped "**No Exception Taken**" and "**Make Corrections Noted**". Our comments are as follows:

1. WCMI Comments:
 - a. We acknowledge receipt of the Additional Submittal Review Comments by WCMI. The Contractor has indicated that the supply blower is being provided by WCMI's HVAC subcontractor and has been approved under Submittal No. 15800-021. **No Exception Taken**
 - b. GMS, Inc. acknowledges that the eyewash shower has been pulled from this submittal and will be provided by a different supplier. **No Exception Taken**
2. Haldeman-Homme, Inc. Response to GMS, Inc. Returned Shop Drawing Comments: The following number references refer to Shop Submittal No. 12346-001A returned to WCMI November 26, 2012 and the referenced specification paragraphs in Specification Section 11610.
 - a. Comment 1.B.2.: We acknowledge the supply blower will be provided by the HVAC contractor. **No Exception Taken**
 - b. Comment 1.D.: The items noted under Specification Section 11610, Paragraph 2.1.D., regarding the modified epoxy resin working surface have been satisfactorily addressed. The reference to Sheet H90-02 should be modified to read H91.02. **No Exception Taken and Make Corrections Noted**

Mr. Wes Weaver
December 13, 2012
Page 2

- c. Comment 1.E.1.: We acknowledge the sash is not a fixed sash. As indicated, only the baffle will be fixed. We take no exception to this arrangement. We acknowledge the reference to Sheet H60.06 which are the paragraphs that raised the question for us on whether this was a fixed sash or an adjustable sash. **No Exception Taken**
- d. Comment 1.F.1.: **No Exception Taken**
- e. Comment 1.F.2.: We acknowledge two receptacles will be placed in the fume hood, one 110V and one 240V, 3-phase receptacle. We request the outlets be configured per the project specification, two 110 VAC and one 208 Volt, single-phase, AC outlets. **Make Corrections Noted**
- f. Comment 1.F.3.: **No Exception Taken**
- g. Comment 1.F.4.: **No Exception Taken**
- h. Comment 1.F.5.: **No Exception Taken**
- i. Comment 1.I.: **No Exception Taken**
- j. , Comment 4.a., Sheet H-20.01: **No Exception Taken**
- k. Comments 8.a. and 8.b., Sheet H50.01: We acknowledge the eyewash shower will be provided by the mechanical subcontractor, rather than this supplier. **No Exception Taken**
- l. Comment 9., Sheet H50.02: We take no exception to the mixing faucet Model L422VB.

Please call if you should have any questions.

Sincerely,



David R. Frisch, P.L.S.

DRF/kmw
Attachments

ec (w/attachments):

- Mr. Jim Heckman, Manager, LFMSDD, lfmanager@lfmsdd.org
- Ms. Cindy Murray, Office Manager, Fountain Sanitation District, fsdistrict@fsd901.org
- Mr. Jeff Burst, Project Supt., Weaver Construction Management, Inc., jeff@weavercm.com
- Mr. John Jacob, Project Mgr., Weaver Construction Management, Inc., john@weavercm.com
- Mr. Adam Roeder, Weaver Construction Management, Inc., aroeder@weavercm.com
- Ms. Leslie Brown, Weaver Construction Management, Inc., leslie@weavercm.com

cc (w/attachments): Mr. Jerry Miller, Resident Project Representative, GMS, Inc.