

GMS, INC.
CONSULTING ENGINEERS
611 NORTH WEBER, SUITE 300
COLORADO SPRINGS, COLORADO 80903-1074

TELEPHONE (719) 475-2935
TELEFAX (719) 475-2938

EDWARD D. MEYER, P.E.
ROGER J. SAMS, P.E.
GREGORY R. WORDEN, P.E.
THOMAS A. McCLENNAN, P.E.

KEN L. WHITE, P.L.S.
DAVID R. FRISCH, P.L.S.
MARK A. MORTON, P.E.
JASON D. MEYER, P.E.

April 2, 2012

Mr. Wes Weaver, President
Weaver Construction Management, Inc.
3679 South Huron Street, Suite 404
Englewood, CO 80110

Via Email to: wes@weavergc.com
No Hard Copy to Follow

Re: Harold D. Thompson Regional Water Reclamation Facility (HDTRWRF)
Lower Fountain Metropolitan Sewage Disposal District (LFMSDD)

Dear Wes:

Reference is made to your shop submittal identified as follows:

Submittal No.:	13121-001B
Date of Submittal:	March 30, 2012
Title:	Equipment and Maintenance (EM) Building Prefabricated Metal Building
Specification Section:	13121 – Prefabricated Metal Building
Manufacturer:	Chief Buildings/Chief Industries, Inc.

The referenced submittal has been stamped "***Make Corrections Noted***". Our comments are as follows:

1. We are in receipt of the WCMI "additional submittal review comments."
2. Sheet A2 of A5:
 - a. We request the supplier review the proposed baseplate configuration with the as-constructed information provide by WCMI. This applies to Detail Q and Detail P. The following are detailed descriptions we find between WCMI as-builts and the proposed baseplate.

	<u>WCMI As-Builts</u>	<u>Proposed Baseplate</u>
Detail Q	21'-11 ⁵ / ₈ "	21'-11 ³ / ₈ "
	2 ¹ / ₈ "	2 ¹ / ₄ "
	2 ⁷ / ₈ "	2 ³ / ₄ "
Detail P	21'-11 ⁵ / ₈ "	21'-11 ³ / ₈ "
	2 ¹ / ₄ "	2 ¹ / ₈ "
	2 ³ / ₄ "	2 ⁷ / ₈ "

Mr. Wes Weaver
April 2, 2012
Page 2

We request Chief Buildings review the as-constructed information provided by WCMI and the proposed design and determine the extent of modifications required.

Please call if you should have any questions.

Sincerely,



David R. Frisch, P.L.S.

DRF/kmw

ec (letter only):

Mr. Jim Heckman, Manager, LFMSDD, lfmanager@lfmsdd.org

Ms. Cindy Murray, Office Manager, Fountain Sanitation District, fsdistrict@fsd901.org

Mr. Jeff Burst, Project Supt., Weaver Construction Management, Inc., jeff@weavercm.com

Mr. John Jacob, Project Mgr., Weaver Construction Management, Inc., john@weavercm.com

Mr. Tyler Ammerman, Weaver Construction Management, Inc., tammerman@weavercm.com

Ms. Leslie Brown, Weaver Construction Management, Inc., leslie@weavercm.com

Mr. Mike Gaines, P.E., MGA Structural Engineers, Inc., mg@mgase.com

cc: Mr. Jerry Miller, Resident Project Representative, GMS, Inc.