

GMS, INC.
CONSULTING ENGINEERS
611 NORTH WEBER, SUITE 300
COLORADO SPRINGS, COLORADO 80903-1074

TELEPHONE (719) 475-2935
TELEFAX (719) 475-2938

EDWARD D. MEYER, P.E.
ROGER J. SAMS, P.E.
GREGORY R. WORDEN, P.E.
THOMAS A. McCLERNAN, P.E.

KEN L. WHITE, P.L.S.
DAVID R. FRISCH, P.L.S.
MARK A. MORTON, P.E.
JASON D. MEYER, P.E.

April 30, 2013

Mr. Wes Weaver, President
Weaver Construction Management, Inc.
c/o Garney Construction
7911 Shaffer Parkway
Littleton, CO 80127

*Via Email to: wes@weavercm.com
No Hard Copy to Follow*

Re: Harold D. Thompson Regional Water Reclamation Facility (HDTRWRF)
Lower Fountain Metropolitan Sewage Disposal District (LFMSDD)

Dear Wes:

Reference is made to your shop submittal identified as follows:

Submittal No.:	13421-001A
Date of Submittal:	April 19, 2013
Title:	Polyethylene Chemical Storage Tank
Specification Section:	13421
Manufacturers:	Tank Equipment; PolyProcessing

The referenced submittal has been stamped "**No Exception Taken**". Our comments are as follows:

1. We take no exception to the proposed fabrication location of Nozzle E indicated on the submitted tank dimensional drawing. However, WCMI must make minor adjustments during the installation process to accommodate this proposed position, as described in the previous review letter Comment Nos. 1.d. and 1.f. This includes reducing the high level alarm and DSP Off elevations of the level instrumentation by 2 inches and adjusting the overflow piping down to the floor drain to avoid interference with the polymer totes.

Please call if you should have any questions.

Sincerely,



Mark A. Morton, P.E.

MAM/kmw

ec (letter only):

Mr. Jim Heckman, Manager, LFMSDD, lfmanager@lfmsdd.org
Ms. Cindy Murray, Office Manager, Fountain Sanitation District, fsdistrict@fsd901.org
Mr. Jeff Burst, Project Supt., Weaver Construction Management, Inc., jeff@weavercm.com
Mr. John Jacob, Project Mgr., Weaver Construction Management, Inc., john@weavercm.com
Mr. Adam Roeder, Weaver Construction Management, Inc., aroeder@weavercm.com
Ms. Solange Huggins, Project Engineer, Garney Construction, shuggins@garney.com

cc (w/attachment): Mr. Jerry Miller, Resident Project Representative, GMS, Inc.