## GMS, INC.

## CONSULTING ENGINEERS 611 NORTH WEBER, SUITE 300 COLORADO SPRINGS, COLORADO 80903-1074

TELEPHONE (719) 475-2935 TELEFAX (719) 475-2938

EDWARD D. MEYER, P.E. ROGER J. SAMS, P.E. GREGORY R. WORDEN, P.E. THOMAS A. McCLERNAN, P.E.

KEN L. WHITE, P.L.S. DAVID R. FRISCH, P.L.S. MARK A. MORTON, P.E. JASON D. MEYER, P.E.

May 25, 2012

Mr. Wes Weaver, President Weaver Construction Management, Inc. 3679 South Huron Street, Suite 404 Englewood, CO 80110

Via Email to: wes@weavercm.com No Hard Copy to Follow

Re:

Harold D. Thompson Regional Water Reclamation Facility (HDTRWRF)

Lower Fountain Metropolitan Sewage Disposal District (LFMSDD)

Dear Wes:

Reference is made to your shop submittal identified as follows:

Submittal No.: 15058-001
Date of Submittal: May 1, 2012

Title: Magnetic Starters at P&D Building

Specification Section: 15058 - Common Motor Requirements for HVAC Equipment

Manufacturer: Cerus

The referenced submittal has been stamped "Make Corrections Noted". Our comments are as follows:

- The magnetic starters are to be omitted. The starters are specified to be included in the motor control center PD-MCCA. Please reference the Electrical Drawings in the "Issued for Construction" drawings dated May 21, 2012.
- 2. The Contractor shall coordinate the fan power and control requirements with the MCC supplier.

Please call if you should have any questions.

Sincerely,

David R. Frisch, P.L.S.

David L. Frisch

DRF/kmw

ec (letter only):

Mr. Jim Heckman, Manager, LFMSDD, Ifmanager@lfmsdd.org

Ms. Cindy Murray, Office Manager, Fountain Sanitation District, fsdistrict@fsd901.org

Mr. Jeff Burst, Project Supt., Weaver Construction Management, Inc., jeff@weavercm.com

Mr. John Jacob, Project Mgr., Weaver Construction Management, Inc., john@weavercm.com

Mr. Tyler Ammerman, Weaver Construction Management, Inc., tammerman@weavercm.com

Ms. Leslie Brown, Weaver Construction Management, Inc., leslie@weavercm.com

cc: Mr. Jerry Miller, Resident Project Representative, GMS, Inc.