

**GMS, INC.**  
CONSULTING ENGINEERS  
611 NORTH WEBER, SUITE 300  
COLORADO SPRINGS, COLORADO 80903-1074

TELEPHONE (719) 475-2935  
TELEFAX (719) 475-2938

EDWARD D. MEYER, P.E.  
ROGER J. SAMS, P.E.  
GREGORY R. WORDEN, P.E.  
THOMAS A. McCLERNAN, P.E.

KEN L. WHITE, P.L.S.  
DAVID R. FRISCH, P.L.S.  
MARK A. MORTON, P.E.  
JASON D. MEYER, P.E.

March 9, 2012

Mr. Wes Weaver, President  
Weaver Construction Management, Inc.  
3679 South Huron Street, Suite 404  
Englewood, CO 80110

*Via Email to: wes@weavercm.com*  
*No Hard Copy to Follow*

Re: Harold D. Thompson Regional Water Reclamation Facility (HDTRWRF)  
Lower Fountain Metropolitan Sewage Disposal District (LFMSDD)

Dear Wes:

Reference is made to your shop submittal identified as follows:

Submittal No.:	15060-001
Date of Submittal:	February 22, 2012
Title:	Black Steel Pipe (Interior Gas Piping) at EM Building
Specification Section:	15060 – Pipe and Pipe Fittings
Manufacturers:	Wheatland Tube Company; Ward Fittings; Charlotte Piping and Foundry Company; Cresline Plastic Pipe Co., Inc.; AB&I Foundry; Kanuf Insulation; Specialty Construction Brands, Inc.; Proto Corp.

The referenced submittal has been stamped "**No Exception Taken**", "**Revise and Resubmit**" and "**Submit Specified Item**". Our comments are as follows:

1. Wheatland Tube Company, ASTM A53 Type E, Grade A Gas Pipe: **No Exception Taken**
2. Wheatland Tube Company, Schedule 40 Natural Gas Service Line: **Submit Specified Item**
  - a. Please submit product data for natural gas service line as specified in Section 15060, Paragraph 2.1.G.
3. Ward Fittings, Copper Tubing and Fittings: **Submit Specified Item**
  - a. Please submit product data for copper tubing and fittings as specified in Section 15060, Paragraph 2.1.B.
4. Charlotte Piping and Foundry Company, Chlorinated Polyvinyl Chloride (CPVC) SDR 11 Pipe: **Revise and Resubmit**
  - a. CPVC SDR 11 pipe is not acceptable. Please submit product data for Schedule 80 PVC 1120 pipe and appurtenances as specified in Section 15060, Paragraph 2.1.C.

Mr. Wes Weaver  
March 9, 2012  
Page 2

5. Cresline Plastic Pipe Co., Inc. Chlorinated Polyvinyl Chloride (CPVC) Pipe: **No Exception Taken**
6. AB&I Foundry, Cast Iron No-Hub Pipe and Fittings System: **No Exception Taken**
7. Accessories and Protective Coatings: **Submit Specified Item**
  - a. Please submit product data for accessories and protective coating per Section 15060, Paragraphs 2.1.L. and 2.1.M.
8. Knauf Insulation GmbH, Earthwool™ Redi-Klad® 1000° Pipe Insulation: **No Exception Taken**
9. Specialty Construction Brands, Inc., Childers® VI-CRYL® CP-10 and CP-11 Weather Barrier Coatings: **No Exception Taken**
10. Proto Corp., LoSMOKE® PVC Fitting Covers and Jacketing: **No Exception Taken**
11. Cross-Linked Polyethylene (PEX) Water Service Tubing: **Submit Specified Item**
  - a. Please submit product data for PEX piping in accordance with Section 15060, Paragraph 2.1.N.

Please call if you should have any questions.

Sincerely,



David R. Frisch, P.L.S.

DRF/kmw

ec (letter only):

Mr. Jim Heckman, Manager, LFMSDD, [lfmanager@lfmsdd.org](mailto:lfmanager@lfmsdd.org)

Ms. Cindy Murray, Office Manager, Fountain Sanitation District, [fsdistrict@fsd901.org](mailto:fsdistrict@fsd901.org)

Mr. Jeff Burst, Project Supt., Weaver Construction Management, Inc., [jeff@weavercm.com](mailto:jeff@weavercm.com)

Mr. John Jacob, Project Mgr., Weaver Construction Management, Inc., [john@weavercm.com](mailto:john@weavercm.com)

Mr. Tyler Ammerman, Weaver Construction Management, Inc., [tammerman@weavercm.com](mailto:tammerman@weavercm.com)

Ms. Leslie Brown, Weaver Construction Management, Inc., [leslie@weavercm.com](mailto:leslie@weavercm.com)

Mr. David Simmons, P.E., Plant Engineering Consultants, Inc., [dsimmons@planteci.com](mailto:dsimmons@planteci.com)

cc: Mr. Jerry Miller, Resident Project Representative, GMS, Inc.