

**GMS, INC.**  
CONSULTING ENGINEERS  
611 NORTH WEBER, SUITE 300  
COLORADO SPRINGS, COLORADO 80903-1074

TELEPHONE (719) 475-2935  
TELEFAX (719) 475-2938

EDWARD D. MEYER, P.E.  
ROGER J. SAMS, P.E.  
GREGORY R. WORDEN, P.E.  
THOMAS A. McCLERNAN, P.E.

KEN L. WHITE, P.L.S.  
DAVID R. FRISCH, P.L.S.  
MARK A. MORTON, P.E.  
JASON D. MEYER, P.E.

May 4, 2012

Mr. Wes Weaver, President  
Weaver Construction Management, Inc.  
3679 South Huron Street, Suite 404  
Englewood, CO 80110

***Via Email to: wes@weavercm.com***  
***No Hard Copy to Follow***

Re: Harold D. Thompson Regional Water Reclamation Facility (HDTRWRF)  
Lower Fountain Metropolitan Sewage Disposal District (LFMSDD)

Dear Wes:

Reference is made to your shop submittal identified as follows:

Submittal No.:	15060-001A
Date of Submittal:	April 4, 2012
Title:	Plumbing Pipe at Equipment, Maintenance & Storage Building
Specification Section:	15060 – Pipe and Pipe Fittings
Manufacturers:	Cerro Flow Products, Inc.; Oatey; Canfield Technologies; Cresline Plastic Pipe Co., Inc.; Uponor, Inc.

The referenced submittal has been stamped "**No Exception Taken**" and "**Submit Specified Item**".  
Our comments are as follows:

1. We acknowledge receipt of WCMI submittal review comments numbered 1 through 7. We provide the following responses in regard to the review comments.
  1. Acknowledged
  2. Acknowledged
  3. Acknowledged. *Note to WCMI:* Prior to installing natural gas service line, the gas service line subcontractor must provide a shop submittal for natural gas service line piping material in accordance with the project specifications.
  4. We acknowledge receipt of the copper tubing and the shop submittals. Typically, copper tubing is used during installation of the water heater and miscellaneous plumbing equipment; therefore, a copper tubing submittal was requested.
  5. Acknowledged
  6. Acknowledged
  7. Acknowledged

Mr. Wes Weaver  
May 4, 2012  
Page 2

2. Cerro Flow Products, Inc. cerrotube™ Copper Tubing: **No Exception Taken**
3. Oatey® No. 5 Lead Free Paste Flux: **No Exception Taken**
4. Canfield Technologies Solder: **No Exception Taken**
5. Cresline Plastic Pipe Co., Inc. PVC Pressure Pipe Schedule 80: **No Exception Taken**
  - a. Schedule 40 and Schedule 80 pipe are listed on the submittal sheet. For the purposes of the Equipment and Maintenance Building, only Schedule 80 pipe is to be used.
6. Uponor, Inc. Cross-Linked Polyethylene (PEX) Water Service Tubing: **Submit Specified Item**
  - a. The shop submittal is a specification section provided by Uponor, Inc. but makes no reference to the products to be furnished for the Equipment and Maintenance Building including:
    - We acknowledge the standard dimension ratio of PEX pipe is SDR 9. We request some information on the submittal indicate the material to be used has a standard dimension ratio of 9.
    - The size of the tubing to provided.
    - The color of the tubing to be provided.

Please call if you should have any questions.

Sincerely,



David R. Frisch, P.L.S.

DRF/kmw

ec (letter only):

Mr. Jim Heckman, Manager, LFMSDD, [lfmanager@lfmsdd.org](mailto:lfmanager@lfmsdd.org)

Ms. Cindy Murray, Office Manager, Fountain Sanitation District, [fsdistrict@fsd901.org](mailto:fsdistrict@fsd901.org)

Mr. Jeff Burst, Project Supt., Weaver Construction Management, Inc., [jeff@weavercm.com](mailto:jeff@weavercm.com)

Mr. John Jacob, Project Mgr., Weaver Construction Management, Inc., [john@weavercm.com](mailto:john@weavercm.com)

Mr. Tyler Ammerman, Weaver Construction Management, Inc., [tammerman@weavercm.com](mailto:tammerman@weavercm.com)

Ms. Leslie Brown, Weaver Construction Management, Inc., [leslie@weavercm.com](mailto:leslie@weavercm.com)

Mr. David Simmons, P.E., Plant Engineering Consultants, Inc., [dsimmons@planteci.com](mailto:dsimmons@planteci.com)

cc: Mr. Jerry Miller, Resident Project Representative, GMS, Inc.