

**GMS, INC.**  
CONSULTING ENGINEERS  
611 NORTH WEBER, SUITE 300  
COLORADO SPRINGS, COLORADO 80903-1074

TELEPHONE (719) 475-2935  
TELEFAX (719) 475-2938

EDWARD D. MEYER, P.E.  
ROGER J. SAMS, P.E.  
GREGORY R. WORDEN, P.E.  
THOMAS A. McCLERNAN, P.E.

KEN L. WHITE, P.L.S.  
DAVID R. FRISCH, P.L.S.  
MARK A. MORTON, P.E.  
JASON D. MEYER, P.E.

September 10, 2012

Mr. Wes Weaver, President  
Weaver Construction Management, Inc.  
3679 South Huron Street, Suite 404  
Englewood, CO 80110

*Via Email to: wes@weavercm.com*  
*No Hard Copy to Follow*

Re: Harold D. Thompson Regional Water Reclamation Facility (HDTRWRF)  
Lower Fountain Metropolitan Sewage Disposal District (LFMSDD)

Dear Wes:

Reference is made to your shop submittal identified as follows:

Submittal No.:	15070-001
Date of Submittal:	August 17, 2012
Title:	Plumbing Pipe Support for Operations Building
Specification Section:	15070
Manufacturer:	B-Line Systems, Inc.

The referenced submittal has been stamped "**No Exception Taken**" and "**Submit Specified Item.**" Our comments are as follows:

1. Based on the electronic mail correspondence from Mesa Plumbing & Heating, Inc., we take no exception to use of galvanized coatings for the swivel hangers proposed in this project.
2. Based on electronic mail correspondence from Mesa Plumbing & Heating, Inc., it is understood they propose to use plain, uncoated steel for clevis pipe hangers. If this understanding is not correct, please notify GMS, Inc.
3. It is anticipated that all piping which will require support with this product are non-metallic materials. Therefore, we take no exception to the use of the product submitted to attain compliance with Specification Section 15070, Paragraph 3.2.B., Requirements to Separate Dissimilar Metals. In the event there are metallic piping materials which require support by the products submitted, it will be necessary that there be a galvanic insulating material between the steel hangers and the metallic piping material. Please submit, under separate cover, any locations where metallic piping material will be used in this particular part of the project.
4. Please provide for conformance with Specification Section 15070, Paragraph 3.2.G., Coating, which requires surface preparation, priming and finish coating of unfinished steel material. As indicated above, please provide a schedule of installation locations and application conditions

Mr. Wes Weaver  
September 10, 2012  
Page 2

where these products will be used with metallic piping. Special coatings and/or other protection to prevent galvanic corrosion will be necessary in accordance with the specifications.

Please call if you should have any questions.

Sincerely,

A handwritten signature in blue ink that reads "Roger J. Sams". The signature is fluid and cursive, with the first letters of each name being capitalized and prominent.

Roger J. Sams, P.E.

RJS/kmw

ec (letter only):

Mr. Jim Heckman, Manager, LFMSDD, [lfmanager@lfmsdd.org](mailto:lfmanager@lfmsdd.org)

Ms. Cindy Murray, Office Manager, Fountain Sanitation District, [fsdistrict@fsd901.org](mailto:fsdistrict@fsd901.org)

Mr. Jeff Burst, Project Supt., Weaver Construction Management, Inc., [jeff@weavercm.com](mailto:jeff@weavercm.com)

Mr. John Jacob, Project Mgr., Weaver Construction Management, Inc., [john@weavercm.com](mailto:john@weavercm.com)

Mr. Adam Roeder, Weaver Construction Management, Inc., [aroeder@weavercm.com](mailto:aroeder@weavercm.com)

Ms. Leslie Brown, Weaver Construction Management, Inc., [leslie@weavercm.com](mailto:leslie@weavercm.com)

cc: Mr. Jerry Miller, Resident Project Representative, GMS, Inc.