

GMS, INC.
CONSULTING ENGINEERS
611 NORTH WEBER, SUITE 300
COLORADO SPRINGS, COLORADO 80903-1074

TELEPHONE (719) 475-2935
TELEFAX (719) 475-2938

EDWARD D. MEYER, P.E.
ROGER J. SAMS, P.E.
GREGORY R. WORDEN, P.E.
THOMAS A. McCLENNAN, P.E.

KEN L. WHITE, P.L.S.
DAVID R. FRISCH, P.L.S.
MARK A. MORTON, P.E.
JASON D. MEYER, P.E.

December 3, 2012

Mr. Wes Weaver, President
Weaver Construction Management, Inc.
3679 South Huron Street, Suite 404
Englewood, CO 80110

Via Email to: wes@weavercm.com
No Hard Copy to Follow

Re: Harold D. Thompson Regional Water Reclamation Facility (HDTRWRF)
Lower Fountain Metropolitan Sewage Disposal District (LFMSDD)

Dear Wes:

Reference is made to your shop submittal identified as follows:

Submittal No.:	15075-001B
Date of Submittal:	November 26, 2012
Title:	Model 2596 Automatic Self-Cleaning Strainer
Specification Section:	15075 – Automatic Strainer
Manufacturer:	Eaton Filtration, LLC

The above referenced submittal has been stamped "**No Exception Taken**" and "**Make Corrections Noted**". Our comments are as follows:

1. We acknowledge the responses to the 7 items in our previous submittal review letter. The following addresses each one of those 7 responses.
 - a. Item No. 1 regarding the common fault alarm output – **No Exception Taken**: No exception is taken to the resubmitted control drawing. WCMI shall parallel together all five (5) independent normally open alarm and status contacts noted in the response letter to ensure that any one of the 5 fault or abnormal conditions described will be recognized and communicated to the SCADA system as a common fault condition.
 - b. Item Nos. 2, 3, 4, 5 and 6: **No Exception Taken**
 - c. Item No. 7 regarding internal coatings – **Make Corrections Noted**: An internal coating system will be required as stated in the project specifications. The data sheets for the ES-302 Paint System, noted as "attached" in the response comments, is not included in this submittal package. Please provide the intended paint system data.

Mr. Wes Weaver
December 3, 2012
Page 2

Please call if you should have any questions.

Sincerely,

A handwritten signature in blue ink, appearing to read 'Mark A. Morton', with a long horizontal flourish extending to the right.

Mark A. Morton, P.E.

MAM/kmw

ec (letter only):

Mr. Jim Heckman, Manager, LFMSDD, lfmanager@lfmsdd.org

Ms. Cindy Murray, Office Manager, Fountain Sanitation District, fsdistrict@fsd901.org

Mr. Jeff Burst, Project Supt., Weaver Construction Management, Inc., jeff@weavercm.com

Mr. John Jacob, Project Mgr., Weaver Construction Management, Inc., john@weavercm.com

Mr. Adam Roeder, Weaver Construction Management, Inc., aroeder@weavercm.com

Ms. Leslie Brown, Weaver Construction Management, Inc., leslie@weavercm.com

cc (w/attachments): Mr. Jerry Miller, Resident Project Representative, GMS, Inc.