

**GMS, INC.**  
CONSULTING ENGINEERS  
611 NORTH WEBER, SUITE 300  
COLORADO SPRINGS, COLORADO 80903-1074

TELEPHONE (719) 475-2935  
TELEFAX (719) 475-2938

EDWARD D. MEYER, P.E.  
ROGER J. SAMS, P.E.  
GREGORY R. WORDEN, P.E.  
THOMAS A. McCLERNAN, P.E.

KEN L. WHITE, P.L.S.  
DAVID R. FRISCH, P.L.S.  
MARK A. MORTON, P.E.  
JASON D. MEYER, P.E.

March 20, 2012

Mr. Wes Weaver, President  
Weaver Construction Management, Inc.  
3679 South Huron Street, Suite 404  
Englewood, CO 80110

*Via Email to: wes@weavergc.com*  
*No Hard Copy to Follow*

Re: Harold D. Thompson Regional Water Reclamation Facility (HDTRWRF)  
Lower Fountain Metropolitan Sewage Disposal District (LFMSDD)

Dear Wes:

Reference is made to your shop submittal identified as follows:

Submittal No.:	15400-005A
Date of Submittal:	March 19, 2012
Title:	Plumbing Fixture Schedule for Equipment & Maintenance Building and Storage Building
Specification Section:	15400 - Plumbing
Manufacturers:	Hammond Valve; Conbraco Industries, Inc./Apollo Valves; Rheem Water Heating; Lambertson Industries

The referenced submittal has been stamped "**No Exception Taken**" and "**Revise and Resubmit**". Our comments are as follows:

1. Page 2 of the shop submittal has WCM submittal review comments.
  - a. Item 1. states the PDV40 is a power ventilated unit. The model proposed for use, Model PRO40E2 is not a power ventilated unit. There is a request if this is an acceptable condition. Our response to the request is **No**.
  - b. Item 2. states the tank lining is "Rheemglas Porcelain Enamel" which is standard for the Rheem model PDV40. We take no exception to the Rheemglas Porcelain Enamel lining.
2. Hammond Valve Model 710 Boiler Drain: **No Exception Taken**
3. Conbraco Industries, Inc. Apollo Valves Model RP40/RP40N/RP40Z Reduced Pressure Principle Backflow Preventer: **No Exception Taken**
4. Conbraco Industries, Inc. Apollo Valves AGD and AGD4A Series Air Gap Drains, Model RP40: **No Exception Taken**

Mr. Wes Weaver  
March 20, 2012  
Page 2

5. Rheem Water Heating, Professional™ Powered Damper Gas Water Heater, Model PRO40E2:  
**Revise and Resubmit**
  - a. The model specified, the Power Direct Vent (PDV) Model PDV40, is the desired model for use and is high altitude compliant. We request the Rheem Model PDV40 or equivalent be submitted on for use in the Equipment and Maintenance Building.
  
6. Lambertson Industries Quality-Line Sinks: **No Exception Taken**
  - a. We acknowledge this unit will be supplied with stainless steel legs and sanitary bullet-type feet as indicated on the submittal.
  
  - b. We acknowledge the tub to be submitted will be supplied as a 14-inch deep tub.

Please call if you should have any questions.

Sincerely,



David R. Frisch, P.L.S.

DRF/kmw

cc (letter only):

Mr. Jim Heckman, Manager, LFMSDD, [lfmanager@lfmsdd.org](mailto:lfmanager@lfmsdd.org)

Ms. Cindy Murray, Office Manager, Fountain Sanitation District, [fsdistrict@fsd901.org](mailto:fsdistrict@fsd901.org)

Mr. Jeff Burst, Project Supt., Weaver Construction Management, Inc., [jeff@weavergc.com](mailto:jeff@weavergc.com)

Mr. John Jacob, Project Mgr., Weaver Construction Management, Inc., [john@weavergc.com](mailto:john@weavergc.com)

Mr. Tyler Ammerman, Weaver Construction Management, Inc., [tammerman@weavergc.com](mailto:tammerman@weavergc.com)

Ms. Leslie Brown, Weaver Construction Management, Inc., [leslie@weavergc.com](mailto:leslie@weavergc.com)

cc: Mr. Jerry Miller, Resident Project Representative, GMS, Inc.