

GMS, INC.
CONSULTING ENGINEERS
611 NORTH WEBER, SUITE 300
COLORADO SPRINGS, COLORADO 80903-1074

TELEPHONE (719) 475-2935
TELEFAX (719) 475-2938

EDWARD D. MEYER, P.E.
ROGER J. SAMS, P.E.
GREGORY R. WORDEN, P.E.
THOMAS A. McCLERNAN, P.E.

KEN L. WHITE, P.L.S.
DAVID R. FRISCH, P.L.S.
MARK A. MORTON, P.E.
JASON D. MEYER, P.E.

October 19, 2012

Mr. Wes Weaver, President
Weaver Construction Management, Inc.
3679 South Huron Street, Suite 404
Englewood, CO 80110

Via Email to: wes@weavercm.com
No Hard Copy to Follow

Re: Harold D. Thompson Regional Water Reclamation Facility (HDTRWRF)
Lower Fountain Metropolitan Sewage Disposal District (LFMSDD)

Dear Wes:

Reference is made to your shop submittal identified as follows:

Submittal No.:	15800-015A
Date of Submittal:	October 17, 2012
Title:	Unit Heaters at P&D Building - UH-1 & UH-2
Specification Section:	15800 – Heating and Ventilating
Manufacturer:	Reznor

The referenced submittal has been stamped "***No Exception Taken***" and "***Make Corrections Noted***". Our comments are as follows:

1. Reznor Model UEAS 260: ***No Exception Taken***
2. Construction Drawing MPD-2 indicates accessories that are to be included with the Reznor heater. These items have not been identified on the shop submittal, but must be provided.
Make Corrections Noted
 - Mount in accordance with the manufacturer's instructions and in accordance with the notes provided on Construction Drawing MPD-2.
 - Provide manufacturer's Option CD3 downturn nozzle.
 - Provide 24-volt thermostat. See plans for location. Set thermostat to 55 deg. F (ADJ.).
 - Install PVC combustion and vent pipes per manufacturer's instructions. Provide manufacturer's concentric adapter. Route vent pipe condensation drain line to nearest floor drain.

Mr. Wes Weaver
October 19, 2012
Page 2

Please call if you should have any questions.

Sincerely,



David R. Frisch, P.L.S.

DRF/kmw

ec (letter only):

Mr. Jim Heckman, Manager, LFMSDD, jfmanager@lfmsdd.org

Ms. Cindy Murray, Office Manager, Fountain Sanitation District, fsdistrict@fsd901.org

Mr. Jeff Burst, Project Supt., Weaver Construction Management, Inc., jeff@weavercm.com

Mr. John Jacob, Project Mgr., Weaver Construction Management, Inc., john@weavercm.com

Mr. Adam Roeder, Weaver Construction Management, Inc., aroeder@weavercm.com

Ms. Leslie Brown, Weaver Construction Management, Inc., leslie@weavercm.com

cc: Mr. Jerry Miller, Resident Project Representative, GMS, Inc.