

GMS, INC.
CONSULTING ENGINEERS
611 NORTH WEBER, SUITE 300
COLORADO SPRINGS, COLORADO 80903-1074

TELEPHONE (719) 475-2935
TELEFAX (719) 475-2938

EDWARD D. MEYER, P.E.
ROGER J. SAMS, P.E.
GREGORY R. WORDEN, P.E.
THOMAS A. McCLENNAN, P.E.

KEN L. WHITE, P.L.S.
DAVID R. FRISCH, P.L.S.
MARK A. MORTON, P.E.
JASON D. MEYER, P.E.

April 22, 2013

Mr. Wes Weaver, President
Weaver Construction Management, Inc.
c/o Garney Construction
7911 Shaffer Parkway
Littleton, CO 80127

Via Email to: wes@weavercm.com
No Hard Copy to Follow

Re: Harold D. Thompson Regional Water Reclamation Facility (HDTRWRF)
Lower Fountain Metropolitan Sewage Disposal District (LFMSDD)

Dear Wes:

Reference is made to your shop submittal identified as follows:

| | |
|------------------------|--|
| Submittal No.: | 15800-026 |
| Date of Submittal: | April 1, 2013 |
| Title: | Louvers, Exhaust Fans, Makeup Air Unit for Biosolids Handling Building |
| Specification Section: | 15800-026 |
| Manufacturer: | Greenheck; Cerrus |

The referenced submittal has been stamped "**Make Corrections Noted**" and "**No Exceptions Taken**". Our comments are as follows:

1. Wall Exhaust Fan (EF-1): **Make Corrections Noted**
 - a. Provide thermostat and two input contracts or relays for auto mode operation per exhaust fan schedule on the Construction Drawings.
2. Makeup Air Unit (MAU-1): **Make Corrections Noted**
 - a. Provide heat only thermostat.
 - b. Provide common remote control panel (NEMA 4X) for MAU1 and EF-1 with HOA switches for each.
3. Wall Louvers (L-1, L-2): **No Exceptions Taken**

Mr. Wes Weaver
April 22, 2013
Page 2

Please call if you should have any questions.

Sincerely,



David R. Frisch, P.L.S.

DRF/kmw

ec (letter only):

Mr. Jim Heckman, Manager, LFMSDD, lfmanager@lfmsdd.org

Ms. Cindy Murray, Office Manager, Fountain Sanitation District, fsdistrict@fsd901.org

Mr. Jeff Burst, Project Supt., Weaver Construction Management, Inc., jeff@weavercm.com

Mr. John Jacob, Project Mgr., Weaver Construction Management, Inc., john@weavercm.com

Mr. Adam Roeder, Weaver Construction Management, Inc., aroeder@weavercm.com

Ms. Solange Huggins, Project Engineer, Garney Construction, shuggins@garney.com

cc (letter only): Mr. Jerry Miller, Resident Project Representative, GMS, Inc.