

**GMS, INC.**  
CONSULTING ENGINEERS  
611 NORTH WEBER, SUITE 300  
COLORADO SPRINGS, COLORADO 80903-1074

TELEPHONE (719) 475-2935  
TELEFAX (719) 475-2938

EDWARD D. MEYER, P.E.  
ROGER J. SAMS, P.E.  
GREGORY R. WORDEN, P.E.  
THOMAS A. McCLERNAN, P.E.

KEN L. WHITE, P.L.S.  
DAVID R. FRISCH, P.L.S.  
MARK A. MORTON, P.E.  
JASON D. MEYER, P.E.

April 22, 2013

Mr. Wes Weaver, President  
Weaver Construction Management, Inc.  
c/o Garney Construction  
7911 Shaffer Parkway  
Littleton, CO 80127

*Via Email to: [wes@weavercm.com](mailto:wes@weavercm.com)  
No Hard Copy to Follow*

Re: Harold D. Thompson Regional Water Reclamation Facility (HDTRWRF)  
Lower Fountain Metropolitan Sewage Disposal District (LFMSDD)

Dear Wes:

Reference is made to your shop submittal identified as follows:

Submittal No.:	15820-003
Date of Submittal:	April 1, 2013
Title:	Duct Accessories – Manual Volume Dampers for Biosolids Handling Building
Specification Sections:	15820
Manufacturer:	Greenheck

The referenced submittal has been stamped "**Make Corrections Noted**". No additional information or resubmittal is required on these items. Our comments are as follows:

1. Duct Accessories – Manual Volume Dampers: **Make Corrections Noted**
  - a. Greenheck is an acceptable manufacturer. Provide aluminum dampers.

Please call if you should have any questions.

Sincerely,



David R. Frisch, P.L.S.

DRF/kmw

ec (letter only):

Mr. Jim Heckman, Manager, LFMSDD, [lmanager@lfmsdd.org](mailto:lmanager@lfmsdd.org)

Ms. Cindy Murray, Office Manager, Fountain Sanitation District, [fsdistrict@fsd901.org](mailto:fsdistrict@fsd901.org)

Mr. Jeff Burst, Project Supt., Weaver Construction Management, Inc., [jeff@weavercm.com](mailto:jeff@weavercm.com)

Mr. John Jacob, Project Mgr., Weaver Construction Management, Inc., [john@weavercm.com](mailto:john@weavercm.com)

Mr. Adam Roeder, Weaver Construction Management, Inc., [aroeder@weavercm.com](mailto:aroeder@weavercm.com)

Ms. Solange Huggins, Project Engineer, Garney Construction, [shuggins@garney.com](mailto:shuggins@garney.com)

cc (w/attachments): Mr. Jerry Miller, Resident Project Representative, GMS, Inc.