

GMS, INC.
CONSULTING ENGINEERS
611 NORTH WEBER, SUITE 300
COLORADO SPRINGS, COLORADO 80903-1074

TELEPHONE (719) 475-2935
TELEFAX (719) 475-2938

EDWARD D. MEYER, P.E.
ROGER J. SAMS, P.E.
GREGORY R. WORDEN, P.E.
THOMAS A. McCLERNAN, P.E.

KEN L. WHITE, P.L.S.
DAVID R. FRISCH, P.L.S.
MARK A. MORTON, P.E.
JASON D. MEYER, P.E.

March 1, 2012

Mr. Wes Weaver, President
Weaver Construction Management, Inc.
3679 South Huron Street, Suite 404
Englewood, CO 80110

*Via Email to: wes@weavercm.com
No Hard Copy to Follow*

Re: Harold D. Thompson Regional Water Reclamation Facility (HDTRWRF)
Lower Fountain Metropolitan Sewage Disposal District (LFMSDD)

Dear Wes:

Reference is made to your shop submittal identified as follows:

Submittal No.:	15855-002
Date of Submittal:	February 21, 2012
Title:	Grilles, Registers and Diffusers for EM Building
Specification Section:	15855 – Diffusers, Registers and Grilles
Manufacturer:	Titus

The referenced submittal has been stamped "**No Exceptions Taken**", "**Make Corrections Noted**", "**Revise and Resubmit**". Our comments are as follows:

- Grille Tag B: **Make Corrections Noted**
 - Please provide a surface-mounted grille as specified.
- Grille Tag C, located on the plan below equipment mark F-1: **Revise and Resubmit**
 - Submit specified product data for grille.
 - Note: Contractor must confirm the drawings are Issued for Construction set, Revision 6, dated January 11, 2012.
- Grille Tag E has been omitted from this building: **No Exception Taken**

Please call if you should have any questions.

Mr. Wes Weaver
March 1, 2012
Page 2

Sincerely,



David R. Frisch, P.L.S.

DRF/kmw

ec (letter only):

Mr. Jim Heckman, Manager, LFMSDD, lfmanager@lfmsdd.org

Ms. Cindy Murray, Office Manager, Fountain Sanitation District, fsdistrict@fsd901.org

Mr. Jeff Burst, Project Supt., Weaver Construction Management, Inc., jeff@weavercm.com

Mr. John Jacob, Project Mgr., Weaver Construction Management, Inc., john@weavercm.com

Mr. Tyler Ammerman, Weaver Construction Management, Inc., tammerman@weavercm.com

Ms. Leslie Brown, Weaver Construction Management, Inc., leslie@weavercm.com

Mr. Chris Freer, Plant Engineering Consultants, Inc., cfreer@planteci.com

cc: Mr. Jerry Miller, Resident Project Representative, GMS, Inc.