GMS, INC.

CONSULTING ENGINEERS 611 NORTH WEBER, SUITE 300 COLORADO SPRINGS, COLORADO 80903-1074

TELEPHONE (719) 475-2935 TELEFAX (719) 475-2938

EDWARD D. MEYER, P.E. ROGER J. SAMS, P.E. GREGORY R. WORDEN, P.E. THOMAS A. McCLERNAN, P.E. KEN L. WHITE, P.L.S.
DAVID R. FRISCH, P.L.S.
MARK A. MORTON, P.E.
JASON D. MEYER, P.E.

May 2, 2012

Mr. Wes Weaver, President Weaver Construction Management, Inc. 3679 South Huron Street, Suite 404 Englewood, CO 80110 Via Email to: wes@weavercm.com No Hard Copy to Follow

Re:

Harold D. Thompson Regional Water Reclamation Facility (HDTRWRF)

Lower Fountain Metropolitan Sewage Disposal District (LFMSDD)

Dear Wes:

Reference is made to your shop submittal identified as follows:

Submittal No.:

16000-001

Date of Submittal:

April 18, 2012

Title:

Electrical Handholes

Specification Section:

16000

Manufacturers:

Vaughn Concrete Products, Inc.; East Jordan Iron Works, Inc.; Dayton Superior; Ready Mix Concrete Co.; BASF The Chemical Company/Master Builders; Oklahoma Steel and

Official Company/Master Ballacis, Officialiona C

Wire; Concrete Sealants, Inc.; Cemex, Inc.

The referenced submittal has been stamped "No Exception Taken". Our comments are as follows:

1. The rim of the handholes must be placed to match finished grade. Handhole adjusting rings may be required to bring rim elevations to finished grade.

Please call if you should have any questions.

Sincerely,

David R. Frisch, P.L.S.

Dani P. Frisch

DRF/kmw

ec (letter only):

Mr. Jim Heckman, Manager, LFMSDD, Ifmanager@lfmsdd.org

Ms. Cindy Murray, Office Manager, Fountain Sanitation District, fsdistrict@fsd901.org

Mr. Jeff Burst, Project Supt., Weaver Construction Management, Inc., jeff@weavercm.com

Mr. John Jacob, Project Mgr., Weaver Construction Management, Inc., john@weavercm.com

Mr. Tyler Ammerman, Weaver Construction Management, Inc., tammerman@weavercm.com

Ms. Leslie Brown, Weaver Construction Management, Inc., leslie@weavercm.com

Mr. Mark Reasinger, P.E., Plant Engineering Consultants, Inc., mreasinger@planteci.com

cc: Mr. Jerry Miller, Resident Project Representative, GMS, Inc.