

GMS, INC.
CONSULTING ENGINEERS
611 NORTH WEBER, SUITE 300
COLORADO SPRINGS, COLORADO 80903-1074

TELEPHONE (719) 475-2935
TELEFAX (719) 475-2938

EDWARD D. MEYER, P.E.
ROGER J. SAMS, P.E.
GREGORY R. WORDEN, P.E.
THOMAS A. McCLERNAN, P.E.

KEN L. WHITE, P.L.S.
DAVID R. FRISCH, P.L.S.
MARK A. MORTON, P.E.
JASON D. MEYER, P.E.

January 29, 2013

Mr. Wes Weaver, President
Weaver Construction Management, Inc.
c/o Garney Construction
7911 Shaffer Parkway
Littleton, CO 80127

Via Email to: wes@weavercm.com
No Hard Copy to Follow

Re: Harold D. Thompson Regional Water Reclamation Facility (HDTRWRF)
Lower Fountain Metropolitan Sewage Disposal District (LFMSDD)

Dear Wes:

Reference is made to your shop submittal identified as follows:

Submittal No.:	16511-004A
Date of Submittal:	January 25, 2013
Title:	Interior and Exterior Lighting for Blower Building - Types A, M and C
Specification Section:	16511 - Interior Lighting; 16521 - Exterior Lighting
Manufacturer:	Columbia Lighting; Hubbell Outdoor Lighting; Lithonia Lighting

The referenced submittal has been stamped "**No Exception Taken**" and "**Make Corrections Noted**". Our comments are as follows:

1. We have corrected our copy of the transmittal cover letter included with this submittal to accurately depict the Submittal Number: 16511-004**A** and Fixture Types A, **M** and C provided in this submittal. Please note these corrections in your records.
2. Fixture Type A: **No Exception Taken.**
3. Fixture Type C: **No Exception Taken.**
4. Fixture Type M: **Make Corrections Noted.**
 - a. Provide the Shielding option of NLWG (no lens, wireguard in door frame) to maintain the 55°C temperature rating and provide minimal protrusion of the wireguard.

Mr. Wes Weaver
January 29, 2013
Page 2

Please call if you should have any questions.

Sincerely,

A handwritten signature in blue ink, appearing to read 'Mark A. Morton', with a long horizontal flourish extending to the right.

Mark A. Morton, P.E.

MAM/lme

ec (letter only):

Mr. Jim Heckman, Manager, LFMSDD, jfmanager@lfmsdd.org

Ms. Cindy Murray, Office Manager, Fountain Sanitation District, fsdistrict@fsd901.org

Mr. Jeff Burst, Project Supt., Weaver Construction Management, Inc., jeff@weavercm.com

Mr. John Jacob, Project Mgr., Weaver Construction Management, Inc., john@weavercm.com

Mr. Adam Roeder, Weaver Construction Management, Inc., aroeder@weavercm.com

Mr. Gerardo Gomez, Garney Construction, ggomez@garney.com

Ms. Solange Huggins, Garney Construction, shuggins@garney.com

Mr. Mark Reasinger, P.E., Plant Engineering Consultants Inc., mreasinger@planteci.com

cc (w/attachments): Mr. Jerry Miller, Resident Project Representative, GMS, Inc.