

**GMS, INC.**  
CONSULTING ENGINEERS  
611 NORTH WEBER, SUITE 300  
COLORADO SPRINGS, COLORADO 80903-1074

TELEPHONE (719) 475-2935  
TELEFAX (719) 475-2938

EDWARD D. MEYER, P.E.  
ROGER J. SAMS, P.E.  
GREGORY R. WORDEN, P.E.  
THOMAS A. McCLENNAN, P.E.

KEN L. WHITE, P.L.S.  
DAVID R. FRISCH, P.L.S.  
MARK A. MORTON, P.E.  
JASON D. MEYER, P.E.

July 26, 2012

Mr. Wes Weaver, President  
Weaver Construction Management, Inc.  
3679 South Huron Street, Suite 404  
Englewood, CO 80110

*Via Email to: wes@weavercm.com*  
*No Hard Copy to Follow*

Re: Harold D. Thompson Regional Water Reclamation Facility (HDTRWRF)  
Lower Fountain Metropolitan Sewage Disposal District (LFMSDD)

Dear Wes:

Reference is made to your shop submittal identified as follows:

Submittal No.:	02641-004
Date of Submittal:	June 26, 2012
Title:	Resilient Seated Butterfly Valve, AWWA Butterfly Valve, Eccentric Plug Valve
Specification Section:	02641-Valves and Accessories, Addendum No. Seven (7)
Manufacturer:	Dezurik

The referenced submittal has been stamped "**No Exception Taken**" and "**Revise and Resubmit**".  
Our comments are as follows:

1. Butterfly Valves (Air Service): **Revise and Resubmit**
  - a. We take no exception to the Dezurik Style BOS resilient seated butterfly valve.
  - b. The seat type and shaft type are EPDM which has an operating temperature up to 250°F. Per the project specifications, all components shall be suitable for a continuous operating temperature of 300°F.
2. Butterfly Valves (Liquid Service): **No Exception Taken**
  - a. We take no exception to the Dezurik Style BAW, 6-inch AWWA C504 rubber-seated butterfly valve.
3. Butterfly Valves (Liquid Service): **No Exception Taken**
  - a. We take no exception to the Dezurik Style BAW, 3-inch AWWA C504 rubber-seated butterfly valve.
4. Plug Valves: **No Exception Taken**
  - a. We take no exception to the Dezurik Style PEC eccentric plug valve with a G Series gear with handwheel operator for the 4-inch, 6-inch and 10-inch sizes.

Mr. Wes Weaver  
July 26, 2012  
Page 2

- b. We take no exception to the Dezurik Style PEC 10-inch eccentric plug valve with the G Series variable worm gear with 2-inch square operator.
- c. We take no exception to the Dezurik Style PEC 4-inch and 6-inch eccentric plug valve with the G Series gear with chain wheel operator.

Please call if you should have any questions.

Sincerely,

A handwritten signature in blue ink that reads "David R. Frisch" with a small "kmw" written below it.

David R. Frisch, P.L.S.

DRF/kmw

ec (letter only):

Mr. Jim Heckman, Manager, LFMSDD, [lfmanager@lfmsdd.org](mailto:lfmanager@lfmsdd.org)

Ms. Cindy Murray, Office Manager, Fountain Sanitation District, [fsdistrict@fsd901.org](mailto:fsdistrict@fsd901.org)

Mr. Jeff Burst, Project Supt., Weaver Construction Management, Inc., [jeff@weavercm.com](mailto:jeff@weavercm.com)

Mr. John Jacob, Project Mgr., Weaver Construction Management, Inc., [john@weavercm.com](mailto:john@weavercm.com)

Ms. Leslie Brown, Weaver Construction Management, Inc., [leslie@weavercm.com](mailto:leslie@weavercm.com)

cc: Mr. Jerry Miller, Resident Project Representative, GMS, Inc.