

GMS, INC.
CONSULTING ENGINEERS
611 NORTH WEBER, SUITE 300
COLORADO SPRINGS, COLORADO 80903-1074

TELEPHONE (719) 475-2935
TELEFAX (719) 475-2938

EDWARD D. MEYER, P.E.
ROGER J. SAMS, P.E.
GREGORY R. WORDEN, P.E.
THOMAS A. McCLERNAN, P.E.

KEN L. WHITE, P.L.S.
DAVID R. FRISCH, P.L.S.
MARK A. MORTON, P.E.
JASON D. MEYER, P.E.

August 14, 2012

Mr. Wes Weaver, President
Weaver Construction Management, Inc.
3679 South Huron Street, Suite 404
Englewood, CO 80110

Via Email to: wes@weavercm.com
No Hard Copy to Follow

Re: Harold D. Thompson Regional Water Reclamation Facility (HDTRWRF)
Lower Fountain Metropolitan Sewage Disposal District (LFMSDD)

Dear Wes:

Reference is made to your shop submittal identified as follows:

Submittal No.:	02641-006
Date of Submittal:	July 16, 2012
Title:	Dezurik Plug Valves and Rotork Electric Actuators
Specification Section:	02641 – Valves and Accessories
Manufacturers:	DeZurik; Tnemec Co., Inc.; Rotork Controls, Inc.

The referenced submittal has been stamped "**No Exception Taken**" and "**Revise and Resubmit**".
Our comments are as follows:

1. We take no exception to the 4" Dezurik PEC plug valve.
2. We take no exception to the Tnemec Epoxoline Series 141 coating proposed for use on the valve.
3. Rotork Electric Actuator: **Revise and Resubmit**
 - a. We acknowledge the proposed actuator is a modulating actuator.
 - b. Based upon the design criteria provided, the actuator is capable of "inching" or regulating valves. We request documentation be provided stating the actuator can be adjusted to a percentage Open or a percentage Close. In addition, we request information be provided for the Rotork electric actuator stating it is compatible with SCADA equipment in providing accurate percentage of Open/Close position of the plug valve.

Mr. Wes Weaver
August 14, 2012
Page 2

Please call if you should have any questions.

Sincerely,



David R. Frisch, P.L.S.

DRF/kmw

ec (letter only):

Mr. Jim Heckman, Manager, LFMSDD, lfmanager@lfmsdd.org

Ms. Cindy Murray, Office Manager, Fountain Sanitation District, fsdistrict@fsd901.org

Mr. Jeff Burst, Project Supt., Weaver Construction Management, Inc., jeff@weavercm.com

Mr. John Jacob, Project Mgr., Weaver Construction Management, Inc., john@weavercm.com

Mr. Adam Roeder, Weaver Construction Management, Inc., aroeder@weavercm.com

Ms. Leslie Brown, Weaver Construction Management, Inc., leslie@weavercm.com

cc: Mr. Jerry Miller, Resident Project Representative, GMS, Inc.