

**GMS, INC.**  
CONSULTING ENGINEERS  
611 NORTH WEBER, SUITE 300  
COLORADO SPRINGS, COLORADO 80903-1074

TELEPHONE (719) 475-2935  
TELEFAX (719) 475-2938

EDWARD D. MEYER, P.E.  
ROGER J. SAMS, P.E.  
GREGORY R. WORDEN, P.E.  
THOMAS A. McCLENNAN, P.E.

KEN L. WHITE, P.L.S.  
DAVID R. FRISCH, P.L.S.  
MARK A. MORTON, P.E.  
JASON D. MEYER, P.E.

January 2, 2013

Mr. Wes Weaver, President  
Weaver Construction Management, Inc.  
3679 South Huron Street, Suite 404  
Englewood, CO 80110

*Via Email to: [wes@weavercm.com](mailto:wes@weavercm.com)  
No Hard Copy to Follow*

Re: Harold D. Thompson Regional Water Reclamation Facility (HDTRWRF)  
Lower Fountain Metropolitan Sewage Disposal District (LFMSDD)

Dear Wes:

Reference is made to your shop submittal identified as follows:

Submittal No.:	02670-001
Date of Submittal:	December 28, 2012
Title:	Well Construction - WWTP Well No. 1
Specification Section:	02670
Manufacturers:	CertainTeed Corporation; Titan Industries, Inc.; Oblebay Norton Industrial Sands; Monitor Division

The referenced submittal has been stamped "**No Exception Taken**". No additional information or resubmittal is required on this item. Our comments are as follows:

1. CertainTeed Corporation Certa-Lok PVC Well Casing: **No Exception Taken**
2. Titan Industries, Inc. 6" Schedule 40 PVC Well Screen: **No Exception Taken**
3. Oglebay Norton Industrial Sands, Colorado Silica Sand™ 10 to 20 Grain Size: **No Exception Taken**
4. Monitor Division Standard Domestic PS Pitless Unit Model 4PS67BNS4CO with the required options:  
**No Exception Taken**
  - a. We acknowledge the adapter is 1¼-inch and it will be reduced to 1-inch for the discharge connection.

Please call if you should have any questions.

Sincerely,



David R. Frisch, P.L.S.

DRF/kmw

ec (letter only):

Mr. Jim Heckman, Manager, LFMSDD, [lfmanager@lfmsdd.org](mailto:lfmanager@lfmsdd.org)  
Ms. Cindy Murray, Office Manager, Fountain Sanitation District, [fsdistrict@fsd901.org](mailto:fsdistrict@fsd901.org)  
Mr. Jeff Burst, Project Supt., Weaver Construction Management, Inc., [jeff@weavercm.com](mailto:jeff@weavercm.com)  
Mr. John Jacob, Project Mgr., Weaver Construction Management, Inc., [john@weavercm.com](mailto:john@weavercm.com)  
Mr. Adam Roeder, Weaver Construction Management, Inc., [aroeder@weavercm.com](mailto:aroeder@weavercm.com)  
Ms. Leslie Brown, Weaver Construction Management, Inc., [leslie@weavercm.com](mailto:leslie@weavercm.com)

cc (w/attachment): Mr. Jerry Miller, Resident Project Representative, GMS, Inc.