

**GMS, INC.**  
CONSULTING ENGINEERS  
611 NORTH WEBER, SUITE 300  
COLORADO SPRINGS, COLORADO 80903-1074

TELEPHONE (719) 475-2935  
TELEFAX (719) 475-2938

EDWARD D. MEYER, P.E.  
ROGER J. SAMS, P.E.  
GREGORY R. WORDEN, P.E.  
THOMAS A. McCLERNAN, P.E.

KEN L. WHITE, P.L.S.  
DAVID R. FRISCH, P.L.S.  
MARK A. MORTON, P.E.  
JASON D. MEYER, P.E.

June 18, 2013

Mr. Wes Weaver, President  
Weaver Construction Management, Inc.  
c/o Garney Construction  
7911 Shaffer Parkway  
Littleton, CO 80127

*Via Email to: [wes@weavercm.com](mailto:wes@weavercm.com)  
No Hard Copy to Follow*

Re: Harold D. Thompson Regional Water Reclamation Facility (HDTRWRF)  
Lower Fountain Metropolitan Sewage Disposal District (LFMSDD)

Dear Wes:

Reference is made to your shop submittal identified as follows:

Submittal No.:	02830-001A
Date of Submittal:	June 6, 2013
Title:	Chain Link Fence and Wireless Intercom
Specification Section:	02830
Manufacturers:	Champion Fence; Maximum Controls, LLC; Weldon)

The referenced submittal has been stamped "**No Exception Taken**" and "**Revise and Resubmit**". Our comments are as follows:

1. We take no exception to the information provided for the Aeromax 200K Long Range Wireless Intercom.
2. The Contractor must take into consideration the mounting of the units at the gate and in the Operations Building when installing the wireless intercom to ensure constant, direct communication between the two units.
3. Project Specifications require the rollers for the gate to be constructed of 4" diameter cold rolled steel. The shop submittal provided indicates a 4" diameter nylon roller is to be provided. We request the rollers be made of cold rolled steel per the Project Specifications. **Revise and Resubmit**

Please call if you should have any questions.

Sincerely,



David R. Frisch, P.L.S.

DRF/kmw

ec (letter only):

Mr. Jim Heckman, Manager, LFMSDD, [lfmanager@lfmsdd.org](mailto:lfmanager@lfmsdd.org)  
Ms. Cindy Murray, Office Manager, Fountain Sanitation District, [fsdistrict@fsd901.org](mailto:fsdistrict@fsd901.org)  
Mr. Jeff Burst, Project Supt., Weaver Construction Management, Inc., [jeff@weavercm.com](mailto:jeff@weavercm.com)  
Mr. John Jacob, Project Mgr., Weaver Construction Management, Inc., [john@weavercm.com](mailto:john@weavercm.com)  
Mr. Adam Roeder, Weaver Construction Management, Inc., [aroeder@weavercm.com](mailto:aroeder@weavercm.com)  
Ms. Solange Huggins, Project Engineer, Garney Construction, [shuggins@garney.com](mailto:shuggins@garney.com)  
cc (w/attachments): Mr. Jerry Miller, Resident Project Representative, GMS, Inc.