

**GMS, INC.**  
CONSULTING ENGINEERS  
611 NORTH WEBER, SUITE 300  
COLORADO SPRINGS, COLORADO 80903-1074

TELEPHONE (719) 475-2935  
TELEFAX (719) 475-2938

EDWARD D. MEYER, P.E.  
ROGER J. SAMS, P.E.  
GREGORY R. WORDEN, P.E.  
THOMAS A. McCLERNAN, P.E.

KEN L. WHITE, P.L.S.  
DAVID R. FRISCH, P.L.S.  
MARK A. MORTON, P.E.  
JASON D. MEYER, P.E.

March 23, 2011

Mr. Wes Weaver, President  
Weaver General Construction Co.  
3679 South Huron Street, Suite 404  
Englewood, CO 80110

***Via Email to: wes@weavergc.com***  
***No Hard Copy to Follow***

Re: Harold D. Thompson Regional Water Reclamation Facility (HDTRWRF)  
Lower Fountain Metropolitan Sewage Disposal District (LFMSDD)

Dear Wes:

Reference is made to your shop submittal identified as follows:

Submittal No.:	03200-007
Date of Submittal:	March 1, 2011
Title:	Concrete Reinforcement for Drilled Piers at Headworks Building, Submittal Drawing P4
Specification Section:	03200
Supplier:	Dalco Industries, Inc.

The referenced submittal has been stamped **"Make Corrections Noted"**. No additional information or resubmittal is required on these items. Please ensure that all comments below are satisfactorily addressed prior to fabrication and/or delivery of the reinforcing. Our comments are as follows:

1. Drilled Pier Schedule
  - a. Revise MK (D) to indicate a quantity of 4.
  - b. Revise MK (F) to indicate a quantity of 2.
  - c. Revise MK (V) to indicate 4 #7x6'-6" with a projection of 3', per Section "A".
  - d. Revise MK (W) to indicate 4 #7x6'-6" with a projection of 3', per Section "A".
  - e. Revise MK (X) to indicate 4 #7x6'-6" with a projection of 3', per Section "A".
  - f. Revise MK (Y) to indicate 4 #7x6'-6" with a projection of 3', per Section "A".
  - g. Revise MK (Z) to indicate 4 #7x6'-6" with a projection of 3', per Section "A".
  - h. Revise MK (AA) to indicate 4 #7x6'-6" with a projection of 3', per Section "A".
  - i. Revise MK (AB) to indicate 4 #7x6'-6" with a projection of 3', per Section "A".
  - j. Revise MK (AC) to indicate 4 #7x6'-6" with a projection of 3', per Section "A".

Mr. Wes Weaver, President  
March 23, 2011  
Page 2

- k. Revise MK (AD) to indicate 4 #7x6'-6" with a projection of 3', per Section "A".
2. Revise MK (D) shown in the plan view at the northwest drilled pier of grit chamber No. 2 to be MK (F).
3. Please ensure all reinforcing will be ASTM A615, Grade 60 steel.

Please call if you should have any questions.

Sincerely,



Mark A. Morton, P.E.

MAM/kmw

ec (letter only except as noted):

Mr. Jim Heckman, Manager, LFMSDD, [lfmanager@lfmsdd.org](mailto:lfmanager@lfmsdd.org)

Ms. Cindy Murray, Office Manager, Fountain Sanitation District, [fsdistrict@qwestoffice.net](mailto:fsdistrict@qwestoffice.net)

Mr. Jeff Burst, Project Superintendent, Weaver General Construction Co., [jeff@weavergc.com](mailto:jeff@weavergc.com)

Ms. Leslie Brown, Weaver General Construction Co., [leslie@weavergc.com](mailto:leslie@weavergc.com)

cc: Mr. Jerry Miller, Resident Project Representative, GMS, Inc. (w/enclosure)