

**GMS, INC.**  
CONSULTING ENGINEERS  
611 NORTH WEBER, SUITE 300  
COLORADO SPRINGS, COLORADO 80903-1074

TELEPHONE (719) 475-2935  
TELEFAX (719) 475-2938

EDWARD D. MEYER, P.E.  
ROGER J. SAMS, P.E.  
GREGORY R. WORDEN, P.E.  
THOMAS A. McCLERNAN, P.E.

KEN L. WHITE, P.L.S.  
DAVID R. FRISCH, P.L.S.  
MARK A. MORTON, P.E.  
JASON D. MEYER, P.E.

November 16, 2011

Mr. Wes Weaver, President  
Weaver Construction Management, Inc.  
3679 South Huron Street, Suite 404  
Englewood, CO 80110

*Via Email to: wes@weavergc.com  
No Hard Copy to Follow*

Re: Harold D. Thompson Regional Water Reclamation Facility (HDTRWRF)  
Lower Fountain Metropolitan Sewage Disposal District (LFMSDD)

Dear Wes:

Reference is made to your shop submittal identified as follows:

Submittal No.:	03200-008A
Date of Submittal:	August 2, 2011
Title:	Reinforcing for Headworks CMU Walls and Site Concrete - Drawings M1 and M2
Specification Section:	03200 – Concrete Reinforcement
Manufacturer:	Dalco Industries, Inc.

The referenced submittal has been stamped "**No Exception Taken**" and "**Make Corrections Noted**".  
Our comments are as follows:

1. Drawing No. M1: **No Exception Taken**
2. Drawing No. M2: **Make Corrections Noted**
  - a. Provide for additional reinforcement in Section "C" as shown in the redlines issued in Shop Submittal No. 03200-008 correspondence dated April 16, 2011. This was provided in the redlined markups issued back to Weaver Construction Management, Inc.
3. All other items noted in prior GMS, Inc. correspondence have been satisfactorily addressed.

Please call if you should have any questions.

Sincerely,



David R. Frisch, P.L.S.

DRF/kmw

ec (letter only):

Mr. Jim Heckman, Manager, LFMSDD, [lfmanager@lfmsdd.org](mailto:lfmanager@lfmsdd.org)  
Ms. Cindy Murray, Office Manager, Fountain Sanitation District, [fsdistrict@fsd901.org](mailto:fsdistrict@fsd901.org)  
Mr. Jeff Burst, Project Supt., Weaver Construction Management, Inc., [jeff@weavergc.com](mailto:jeff@weavergc.com)  
Mr. John Jacob, Project Mgr., Weaver Construction Management, Inc., [john@weavergc.com](mailto:john@weavergc.com)  
Mr. Tyler Ammerman, Weaver Construction Management, Inc., [tammerman@weavergc.com](mailto:tammerman@weavergc.com)  
Ms. Leslie Brown, Weaver Construction Management, Inc., [leslie@weavergc.com](mailto:leslie@weavergc.com)

cc: Mr. Jerry Miller, Resident Project Representative, GMS, Inc.