

GMS, INC.
CONSULTING ENGINEERS
611 NORTH WEBER, SUITE 300
COLORADO SPRINGS, COLORADO 80903-1074

TELEPHONE (719) 475-2935
TELEFAX (719) 475-2938

EDWARD D. MEYER, P.E.
ROGER J. SAMS, P.E.
GREGORY R. WORDEN, P.E.
THOMAS A. McCLERNAN, P.E.

KEN L. WHITE, P.L.S.
DAVID R. FRISCH, P.L.S.
MARK A. MORTON, P.E.
JASON D. MEYER, P.E.

October 7, 2010

Mr. Wes Weaver, President
Weaver General Construction Co.
3679 South Huron Street, Suite 404
Englewood, CO 80110

***Via Email to: wes@weavergc.com
No Hard Copy to Follow***

Re: Harold D. Thompson Regional Water Reclamation Facility (HDTRWRF)
Lower Fountain Metropolitan Sewage Disposal District (LFMSDD)

Dear Wes:

Reference is made to your shop submittal identified as follows:

Submittal No.:	03300-004
Date of Submittal:	September 27, 2010
Title:	Waterstop
Specification Section:	03300
Manufacturer:	Greenstreak Group, Inc.

The referenced submittal has been stamped "**No Exception Taken**". No additional information or resubmittal is required on this item.

Please call if you should have any questions.

Sincerely,



Roger J. Sams, P.E.

RJS/kmw

cc (letter only):

Mr. Jim Heckman, Manager, LFMSDD, lfmanager@lfmsdd.org
Mr. Jerry Miller, Resident Project Representative, GMS, Inc.
Ms. Leslie Brown, Weaver General Construction Co., leslie@weavergc.com