

GMS, INC.
CONSULTING ENGINEERS
611 NORTH WEBER, SUITE 300
COLORADO SPRINGS, COLORADO 80903-1074

TELEPHONE (719) 475-2935
TELEFAX (719) 475-2938

EDWARD D. MEYER, P.E.
ROGER J. SAMS, P.E.
GREGORY R. WORDEN, P.E.
THOMAS A. McCLERNAN, P.E.

KEN L. WHITE, P.L.S.
DAVID R. FRISCH, P.L.S.
MARK A. MORTON, P.E.
JASON D. MEYER, P.E.

October 7, 2010

Mr. Wes Weaver, President
Weaver General Construction Co.
3679 South Huron Street, Suite 404
Englewood, CO 80110

*Via Email to: wes@weavergc.com
No Hard Copy to Follow*

Re: Harold D. Thompson Regional Water Reclamation Facility (HDTRWRF)
Lower Fountain Metropolitan Sewage Disposal District (LFMSDD)

Dear Wes:

Reference is made to your shop submittal identified as follows:

| | |
|------------------------|-----------------------------|
| Submittal No.: | 03300-006 |
| Date of Submittal: | September 27, 2010 |
| Title: | Multicoat EVA Bonding Agent |
| Specification Section: | 03300 |
| Manufacturer: | US Spec |

The referenced submittal has been stamped "**No Exception Taken**". No additional information or resubmittal is required on this item. Our comments are as follows:

1. Please communicate to all parties to the work that this product IS NOT to be used in locations subject to water immersion. It SHALL NOT be used as a bonding agent for concrete patching below the high water line in any water-containing tank, basin, channel or other similar condition.
2. If a bonding agent may be used in locations subject to water immersion, please submit an appropriate alternative product.

Please call if you should have any questions.

Sincerely,



Roger J. Sams, P.E.

RJS/kmw

cc (letter only):

Mr. Jim Heckman, Manager, LFMSDD, lfmanager@lfmsdd.org
Mr. Jerry Miller, Resident Project Representative, GMS, Inc.
Ms. Leslie Brown, Weaver General Construction Co., leslie@weavergc.com