

**GMS, INC.**  
CONSULTING ENGINEERS  
611 NORTH WEBER, SUITE 300  
COLORADO SPRINGS, COLORADO 80903-1074

TELEPHONE (719) 475-2935  
TELEFAX (719) 475-2938

EDWARD D. MEYER, P.E.  
ROGER J. SAMS, P.E.  
GREGORY R. WORDEN, P.E.  
THOMAS A. McCLERNAN, P.E.

KEN L. WHITE, P.L.S.  
DAVID R. FRISCH, P.L.S.  
MARK A. MORTON, P.E.  
JASON D. MEYER, P.E.

June 15, 2011

Mr. Wes Weaver, President  
Weaver General Construction Co.  
3679 South Huron Street, Suite 404  
Englewood, CO 80110

*Via Email to: wes@weavergc.com  
No Hard Copy to Follow*

Re: Harold D. Thompson Regional Water Reclamation Facility (HDTRWRF)  
Lower Fountain Metropolitan Sewage Disposal District (LFMSDD)

Dear Wes:

Reference is made to your shop submittal identified as follows:

Submittal No.:	03300-013
Date of Submittal:	June 6, 2011
Title:	Concrete Curing Materials for Secondary Clarifiers
Specification Section:	03300
Manufacturers:	Dayton Superior; McDonald Technology Group; McTech Group, Inc.

The referenced submittal has been stamped "**No Exception Taken**". No additional information or resubmittal is required on this item. Our comments are as follows:

1. The submittal documents did not specify locations of intended use for each of the two submitted products. In response to a request for clarification on this point, John Jacob, with WGCC, verified by e-mail on June 17, 2011 that the liquid membrane curing product is intended for use on wall installations, and the blanket curing product is intended for use on slab surfaces. We take no exception to this approach.

Please call if you should have any questions.

Sincerely,



Mark A. Morton, P.E.

MAM/kmw

ec (letter only):

Mr. Jim Heckman, Manager, LFMSDD, [lfmanager@lfmsdd.org](mailto:lfmanager@lfmsdd.org)

Ms. Cindy Murray, Office Manager, Fountain Sanitation District, [fsdistrict@qwestoffice.net](mailto:fsdistrict@qwestoffice.net)

Mr. Jeff Burst, Project Superintendent, Weaver General Construction Co., [jeff@weavergc.com](mailto:jeff@weavergc.com)

Mr. John Jacob, Project Manager, Weaver General Construction Co., [john@weavergc.com](mailto:john@weavergc.com)

Ms. Leslie Brown, Weaver General Construction Co., [leslie@weavergc.com](mailto:leslie@weavergc.com)

cc: Mr. Jerry Miller, Resident Project Representative, GMS, Inc.