

GMS, INC.
CONSULTING ENGINEERS
611 NORTH WEBER, SUITE 300
COLORADO SPRINGS, COLORADO 80903-1074

TELEPHONE (719) 475-2935
TELEFAX (719) 475-2938

EDWARD D. MEYER, P.E.
ROGER J. SAMS, P.E.
GREGORY R. WORDEN, P.E.
THOMAS A. McCLERNAN, P.E.

KEN L. WHITE, P.L.S.
DAVID R. FRISCH, P.L.S.
MARK A. MORTON, P.E.
JASON D. MEYER, P.E.

August 31, 2011

Mr. Wes Weaver, President
Weaver Construction Management, Inc.
3679 South Huron Street, Suite 404
Englewood, CO 80110

Via Email to: wes@weavergc.com
No Hard Copy to Follow

Re: Harold D. Thompson Regional Water Reclamation Facility (HDTRWRF)
Lower Fountain Metropolitan Sewage Disposal District (LFMSDD)

Dear Wes:

Reference is made to your shop submittal identified as follows:

Submittal No.:	03300-019
Date of Submittal:	August 29, 2011
Title:	Concrete Mix Design (3" Max. Slump) for Concrete Footings & Grade Beams - Equipment-Maintenance Building
Specification Section:	03300
Manufacturer:	Transit Mix Concrete Co.; BASF Corporation

The referenced submittal has been stamped "**No Exception Taken**". No additional information or resubmittal is required on this item. Our comments are as follows:

1. The submittal transmittal cover sheet indicates the concrete mix design is for a 3" maximum slump. The mix design submitted is for a 3" to 5" slump. The Equipment and Maintenance Building has no liquid-containing structures within the building. Therefore, we will accept up to a 4" maximum slump for concrete footings and grade beams for this building. Concrete in excess of the 4" maximum slump will be considered out of specification in accordance with Specification Section 03300, Paragraph 2.2.D.6.d.

Please call if you should have any questions.

Sincerely,



David R. Frisch, P.L.S.

DRF/kmw

ec (letter only):

Mr. Jim Heckman, Manager, LFMSDD, lfmanager@lfmsdd.org
Ms. Cindy Murray, Office Manager, Fountain Sanitation District, fsdistrict@fsd901.org
Mr. Jeff Burst, Project Supt., Weaver Construction Management, Inc., jeff@weavergc.com
Mr. John Jacob, Project Mgr., Weaver Construction Management, Inc., john@weavergc.com
Ms. Leslie Brown, Weaver Construction Management, Inc., leslie@weavergc.com
Mr. Mike Gaines, P.E., MGA Structural Engineers, mg@mgase.com

cc (letter only): Mr. Jerry Miller, Resident Project Representative, GMS, Inc.