

GMS, INC.
CONSULTING ENGINEERS
611 NORTH WEBER, SUITE 300
COLORADO SPRINGS, COLORADO 80903-1074

TELEPHONE (719) 475-2935
TELEFAX (719) 475-2938

EDWARD D. MEYER, P.E.
ROGER J. SAMS, P.E.
GREGORY R. WORDEN, P.E.
THOMAS A. McCLERNAN, P.E.

KEN L. WHITE, P.L.S.
DAVID R. FRISCH, P.L.S.
MARK A. MORTON, P.E.
JASON D. MEYER, P.E.

August 31, 2011

Mr. Wes Weaver, President
Weaver Construction Management, Inc.
3679 South Huron Street, Suite 404
Englewood, CO 80110

*Via Email to: wes@weavergc.com
No Hard Copy to Follow*

Re: Harold D. Thompson Regional Water Reclamation Facility (HDTRWRF)
Lower Fountain Metropolitan Sewage Disposal District (LFMSDD)

Dear Wes:

Reference is made to your shop submittal identified as follows:

Submittal No.:	03300-020
Date of Submittal:	August 29, 2011
Title:	Concrete Mix Design (Air-Entrained 4" Max. Slump) for Exterior Slabs-on-Grade
Specification Section:	03300
Manufacturer:	Transit Mix Concrete Co.; BASF Corporation

The referenced submittal has been stamped "**No Exception Taken**". No additional information or resubmittal is required on this item. Our comments are as follows:

1. This shop submittal for cast-in-place concrete exterior slabs on grade, air-entrained 4" maximum slump is an acceptable concrete mix design for the exterior slabs on grade.
2. We note, this mix design is the same as that submitted in Shop Submittal 03300-019. In as much as we take no exception to the mix design, the maximum slump per Specification Section 03300, Paragraph 2.2.D.6.d. is 4". The mix design submitted is for a 3" to 5" slump. As noted in our response letter for Shop Submittal 03300-019, concrete delivered to the site in excess of the 4" maximum slump will be considered out of specification and rejected.

Please call if you should have any questions.

Sincerely,



David R. Frisch, P.L.S.

DRF/kmw

ec (letter only):

Mr. Jim Heckman, Manager, LFMSDD, lfmanager@lfmsdd.org

Ms. Cindy Murray, Office Manager, Fountain Sanitation District, fsdistrict@fsd901.org

Mr. Jeff Burst, Project Supt., Weaver Construction Management, Inc., jeff@weavergc.com

Mr. John Jacob, Project Mgr., Weaver Construction Management, Inc., john@weavergc.com

Ms. Leslie Brown, Weaver Construction Management, Inc., leslie@weavergc.com

Mr. Mike Gaines, P.E., MGA Structural Engineers, mg@mgase.com

cc (letter only): Mr. Jerry Miller, Resident Project Representative, GMS, Inc.