

GMS, INC.
CONSULTING ENGINEERS
611 NORTH WEBER, SUITE 300
COLORADO SPRINGS, COLORADO 80903-1074

TELEPHONE (719) 475-2935
TELEFAX (719) 475-2938

EDWARD D. MEYER, P.E.
ROGER J. SAMS, P.E.
GREGORY R. WORDEN, P.E.
THOMAS A. McCLERNAN, P.E.

KEN L. WHITE, P.L.S.
DAVID R. FRISCH, P.L.S.
MARK A. MORTON, P.E.
JASON D. MEYER, P.E.

October 4, 2011

Mr. Wes Weaver, President
Weaver Construction Management, Inc.
3679 South Huron Street, Suite 404
Englewood, CO 80110

*Via Email to: wes@weavergc.com
No Hard Copy to Follow*

Re: Harold D. Thompson Regional Water Reclamation Facility (HDTRWRF)
Lower Fountain Metropolitan Sewage Disposal District (LFMSDD)

Dear Wes:

Reference is made to your shop submittal identified as follows:

Submittal No.:	03300-021
Date of Submittal:	September 15, 2011
Title:	Cast-in-Place Concrete Mix for Equipment & Maintenance Building Interior Slabs - 4500 psi, Non-Air Entrained
Specification Section:	03300
Manufacturers:	Transit Mix Concrete Co.; BASF Corporation

The referenced submittal has been stamped "**No Exception Taken**". Our comments are as follows:

1. The submittal transmittal letter indicates there is no deviation from spec. There is a deviation from spec and we request that any deviation from spec be noted on the submittal transmittal letter.
2. Concrete mix design No. 34502010 for the interior slab-on-grade is a non-air entrained concrete mix design. In as much as we take no exception to this mix design for the Equipment and Maintenance Building, Specification Section 03300 does not provide for a non-air entrained mix. For the purposes of this submittal, we take no exception to this mix design for the Equipment and Maintenance Building only.

Please call if you should have any questions.

Sincerely,



David R. Frisch, P.L.S.

DRF/kmw

ec (letter only):

Mr. Jim Heckman, Manager, LFMSDD, lfmanager@lfmsdd.org
Ms. Cindy Murray, Office Manager, Fountain Sanitation District, fsdistrict@fsd901.org
Mr. Jeff Burst, Project Supt., Weaver Construction Management, Inc., jeff@weavergc.com
Mr. John Jacob, Project Mgr., Weaver Construction Management, Inc., john@weavergc.com
Ms. Leslie Brown, Weaver Construction Management, Inc., leslie@weavergc.com

cc (w/enclosure):

Mr. Jerry Miller, Resident Project Representative, GMS, Inc.