

GMS, INC.
CONSULTING ENGINEERS
611 NORTH WEBER, SUITE 300
COLORADO SPRINGS, COLORADO 80903-1074

TELEPHONE (719) 475-2935
TELEFAX (719) 475-2938

EDWARD D. MEYER, P.E.
ROGER J. SAMS, P.E.
GREGORY R. WORDEN, P.E.
THOMAS A. McCLENNAN, P.E.

KEN L. WHITE, P.L.S.
DAVID R. FRISCH, P.L.S.
MARK A. MORTON, P.E.
JASON D. MEYER, P.E.

March 15, 2013

Mr. Wes Weaver, President
Weaver Construction Management, Inc.
c/o Garney Construction
7911 Shaffer Parkway
Littleton, CO 80127

***Via Email to: wes@weavercm.com
No Hard Copy to Follow***

Re: Harold D. Thompson Regional Water Reclamation Facility (HDTRWRF)
Lower Fountain Metropolitan Sewage Disposal District (LFMSDD)

Dear Wes:

Reference is made to your shop submittal identified as follows:

Submittal No.:	03300-027A
Date of Submittal:	March 14, 2013
Title:	Cast-In-Place Structural Concrete Mix Designs – Biosolids Handling Complex
Specification Section:	03300
Manufacturer:	Transit Mix Concrete Co.; BASF Corporation

The referenced submittal has been stamped "**No Exception Taken**". No additional information or resubmittal is required on this item. Our comments are as follows:

1. The submittal transmittal cover sheet indicates the concrete mix design is for a 3" maximum slump. The mix design on page 4 of the submittal references a 3" to 5" slump. The Biosolids Handling Complex has no liquid-containing structures within the building. Therefore, we will accept up to a 4" maximum slump for concrete footings and grade beams for this building. Concrete in excess of the 4" maximum slump will be considered out of specification in accordance with Specification Section 03300, Paragraph 2.2.D.6.d.

Please call if you should have any questions.

Sincerely,



David R. Frisch, P.L.S.

DRF/kmw

ec (letter only):

Mr. Jim Heckman, Manager, LFMSDD, lfmanager@lfmsdd.org
Ms. Cindy Murray, Office Manager, Fountain Sanitation District, fsdistrict@fsd901.org
Mr. Jeff Burst, Project Supt., Weaver Construction Management, Inc., jeff@weavercm.com
Mr. John Jacob, Project Mgr., Weaver Construction Management, Inc., john@weavercm.com
Mr. Adam Roeder, Weaver Construction Management, Inc., aroeder@weavercm.com
Mr. Gerardo Gomez, Garney Construction, ggomez@garney.com
Ms. Solange Huggins, Project Engineer, Garney Construction, shuggins@garney.com

cc (letter only): Mr. Jerry Miller, Resident Project Representative, GMS, Inc.