

GMS, INC.
CONSULTING ENGINEERS
611 NORTH WEBER, SUITE 300
COLORADO SPRINGS, COLORADO 80903-1074

TELEPHONE (719) 475-2935
TELEFAX (719) 475-2938

EDWARD D. MEYER, P.E.
ROGER J. SAMS, P.E.
GREGORY R. WORDEN, P.E.
THOMAS A. McCLERNAN, P.E.

KEN L. WHITE, P.L.S.
DAVID R. FRISCH, P.L.S.
MARK A. MORTON, P.E.
JASON D. MEYER, P.E.

October 12, 2011

Mr. Wes Weaver, President
Weaver Construction Management, Inc.
3679 South Huron Street, Suite 404
Englewood, CO 80110

*Via Email to: wes@weavergc.com
No Hard Copy to Follow*

Re: Harold D. Thompson Regional Water Reclamation Facility (HDTRWRF)
Lower Fountain Metropolitan Sewage Disposal District (LFMSDD)

Dear Wes:

Reference is made to your shop submittal identified as follows:

Submittal No.:	04150-001A
Date of Submittal:	October 3, 2011
Title:	Masonry Accessories: Horizontal Joint Reinforcing, Control Joint and Masonry Insulation
Specification Section:	04150
Manufacturers:	Dayton Superior; Perlite Institute, Inc.

The referenced submittal has been stamped "**No Exception Taken**" and "**Submit Specified Item**". Our comments are as follows:

1. Vertical Reinforcing: We acknowledge receipt of the vertical reinforcing in Submittal No. 03200-008A.
2. Control Joint: Per the supporting documentation provided by Josh Cronholm with Ammex Masonry, Inc., we take no exception to the use of the proposed control joint material consisting of 5/8-inch thick PVC.
3. Perlite Loose Fill Masonry Insulation: Please reference response No. 4 in Submittal No. 04150-001 which states, "**Please submit the manufacturer's certification letter.**" This request is in accordance with the project specifications and in accordance with the Guide Specifications submitted in the original submittal document and this resubmittal which states, "...the manufacturer shall furnish a certificate to the architect or owner stating the product conforms to the Standard Specifications for Silicone Treated Perlite Loose Fill Insulation as adopted and published by Perlite Institute, Inc." We request the certification letter be provided.

Mr. Wes Weaver
October 12, 2011
Page 2

Please call if you should have any questions.

Sincerely,



David R. Frisch, P.L.S.

DRF/kmw

ec (letter only):

Mr. Jim Heckman, Manager, LFMSDD, lfmanager@lfmsdd.org

Ms. Cindy Murray, Office Manager, Fountain Sanitation District, fsdistrict@fsd901.org

Mr. Jeff Burst, Project Supt., Weaver Construction Management, Inc., jeff@weavergc.com

Mr. John Jacob, Project Mgr., Weaver Construction Management, Inc., john@weavergc.com

Mr. Tyler Ammerman, Weaver Construction Management, Inc., tammerman@weavergc.com

Ms. Leslie Brown, Weaver Construction Management, Inc., leslie@weavergc.com

cc: Mr. Jerry Miller, Resident Project Representative, GMS, Inc.