

GMS, INC.
CONSULTING ENGINEERS
611 NORTH WEBER, SUITE 300
COLORADO SPRINGS, COLORADO 80903-1074

TELEPHONE (719) 475-2935
TELEFAX (719) 475-2938

EDWARD D. MEYER, P.E.
ROGER J. SAMS, P.E.
GREGORY R. WORDEN, P.E.
THOMAS A. McCLENNAN, P.E.

KEN L. WHITE, P.L.S.
DAVID R. FRISCH, P.L.S.
MARK A. MORTON, P.E.
JASON D. MEYER, P.E.

November 25, 2011

Mr. Wes Weaver, President
Weaver Construction Management, Inc.
3679 South Huron Street, Suite 404
Englewood, CO 80110

*Via Email to: wes@weavergc.com
No Hard Copy to Follow*

Re: Harold D. Thompson Regional Water Reclamation Facility (HDTRWRF)
Lower Fountain Metropolitan Sewage Disposal District (LFMSDD)

Dear Wes:

Reference is made to your shop submittal identified as follows:

Submittal No.:	04150-001.C
Date of Submittal:	November 22, 2011
Title:	Masonry (CMU) Insulation: Core-Fill 500 Insulation
Specification Section:	04150 - Masonry Accessories
Manufacturer:	Tailored Chemical Products, Inc.

The referenced submittal has been stamped **"No Exception Taken"** subject to the comments below. No additional information or resubmittal is required on this item. Our comments are as follows:

1. Please provide for installation filling the CMU cavity from the top of the uncapped wall as represented in the submittal data, page 2. Drilling holes through the mortar joints with subsequent patching is not desired.
2. By submittal of this material, it is understood that Weaver Construction Management Inc. has made a determination that this material and installation is compliant with the Pikes Peak Regional Building Code.
3. We understand that this material will be utilized in the Headworks Building in lieu of the previously submitted and accepted Perlite® loose fill insulation.

Please call if you should have any questions.

Sincerely,



Roger J. Sams, P.E.

RJS/lme

ec (letter only):

Mr. Jim Heckman, Manager, LFMSDD, lfmanager@lfmsdd.org
Ms. Cindy Murray, Office Manager, Fountain Sanitation District, fsdistrict@fsd901.org
Mr. Jeff Burst, Project Supt., Weaver Construction Management, Inc., jeff@weavergc.com
Mr. John Jacob, Project Mgr., Weaver Construction Management, Inc., john@weavergc.com
Mr. Tyler Ammerman, Weaver Construction Management, Inc., tammerman@weavergc.com
Ms. Leslie Brown, Weaver Construction Management, Inc., leslie@weavergc.com

cc: Mr. Jerry Miller, Resident Project Representative, GMS, Inc.