

GMS, INC.
CONSULTING ENGINEERS
611 NORTH WEBER, SUITE 300
COLORADO SPRINGS, COLORADO 80903-1074

TELEPHONE (719) 475-2935
TELEFAX (719) 475-2938

EDWARD D. MEYER, P.E.
ROGER J. SAMS, P.E.
GREGORY R. WORDEN, P.E.
THOMAS A. McCLENNAN, P.E.

KEN L. WHITE, P.L.S.
DAVID R. FRISCH, P.L.S.
MARK A. MORTON, P.E.
JASON D. MEYER, P.E.

September 16, 2011

Mr. Wes Weaver, President
Weaver Construction Management, Inc.
3679 South Huron Street, Suite 404
Englewood, CO 80110

*Via Email to: wes@weavergc.com
No Hard Copy to Follow*

Re: Harold D. Thompson Regional Water Reclamation Facility (HDTRWRF)
Lower Fountain Metropolitan Sewage Disposal District (LFMSDD)

Dear Wes:

Reference is made to your shop submittal identified as follows:

Submittal No.:	05500-002A
Date of Submittal:	September 7, 2011
Title:	Shop Drawings SD-01 Through SD-24 for Stairs; Galvanizing; Handrails; Aluminum Grating; Adhesive Anchoring System
Specification Section:	05500
Manufacturer:	American Fabricators, Inc.; North American Galvanizing Company; Drexel Supply Co.; Hilti; Lapeyre Stair, Inc.

The referenced submittal has been stamped "**Make Corrections Noted**". Our comments are as follows:

1. Drawing SD-05: The redline markups prepared by the structural engineer in response to Shop Submittal No. 05500-002 show the weld for Section A to be a shop weld, rather than a field weld. Please make the correction noted.
2. Drawing SD-09: The redline markups prepared by the structural engineer in response to Shop Submittal No. 05500-002 show the weld detail on the lower right hand corner of the sheet to be a "WELD BOTH SIDES", contrary to what is shown on the revised drawings. Please make the correction noted.

Please call if you should have any questions.

Sincerely,



David R. Frisch, P.L.S.

DRF/kmw

ec (letter only):

Mr. Jim Heckman, Manager, LFMSDD, lfmanager@lfmsdd.org
Ms. Cindy Murray, Office Manager, Fountain Sanitation District, fsdistrict@fsd901.org
Mr. Jeff Burst, Project Supt., Weaver Construction Management, Inc., jeff@weavergc.com
Mr. John Jacob, Project Mgr., Weaver Construction Management, Inc., john@weavergc.com
Ms. Leslie Brown, Weaver Construction Management, Inc., leslie@weavergc.com
Mr. Mike Gaines, P.E., MGA Structural Engineers, mg@mgase.com

cc (w/attachment):

Mr. Jerry Miller, Resident Project Representative, GMS, Inc.