

GMS, INC.
CONSULTING ENGINEERS
611 NORTH WEBER, SUITE 300
COLORADO SPRINGS, COLORADO 80903-1074

TELEPHONE (719) 475-2935
TELEFAX (719) 475-2938

EDWARD D. MEYER, P.E.
ROGER J. SAMS, P.E.
GREGORY R. WORDEN, P.E.
THOMAS A. McCLERNAN, P.E.

KEN L. WHITE, P.L.S.
DAVID R. FRISCH, P.L.S.
MARK A. MORTON, P.E.
JASON D. MEYER, P.E.

January 18, 2012

Mr. Wes Weaver, President
Weaver Construction Management, Inc.
3679 South Huron Street, Suite 404
Englewood, CO 80110

Via Email to: wes@weavergc.com
No Hard Copy to Follow

Re: Harold D. Thompson Regional Water Reclamation Facility (HDTRWRF)
Lower Fountain Metropolitan Sewage Disposal District (LFMSDD)

Dear Wes:

Reference is made to your shop submittal identified as follows:

Submittal Nos.:	05500-005C
Date of Submittal:	January 16, 2012
Title:	Aeration Basin/Digester Structure, Clarifiers and Pumping and Disinfection Building Handrail System
Specification Section:	05500 – Metal Fabrications
Manufacturers:	Rocky Mountain Railings; Alcoa Distribution and Industrial Products; Marson; Tnemec Company Incorporated; Hilti, Inc.; Rice Engineering

The referenced submittal has been stamped "**No Exception Taken**" and "**Submit Specified Item**". Our comments are as follows:

1. We take no exception to the handrail system proposed with the posts fabricated to extend 4 feet above the top handrail.
2. Note No. 2 on page 2 of the shop submittal under "*Submittal Review Comments*" states, "They are proposing a continuous rail 4' above the top rail..." Based upon our understanding of the nomenclature used for the handrail components, the rails run horizontally and the posts run vertically. The note indicates it will be a continuous rail 4 feet above the top rail. We request confirmation be provided that the "...rail 4' above the top rail..." is in fact a vertical post rather than a rail.
3. We request the Contractor and handrail fabricator/supplier confirm the end pieces detailed as BOTTOM RAKE P-END as shown on Drawing D-1 will abut the railing for the walkway provided with the Walker Process equipment.

Mr. Wes Weaver
January 18, 2012
Page 2

Please call if you should have any questions.

Sincerely,

A handwritten signature in blue ink that reads "David R. Frisch". The signature is written in a cursive style.

David R. Frisch, P.L.S.

DRF/kmw

ec (letter only):

Mr. Jim Heckman, Manager, LFMSDD, lfmanager@lfmsdd.org

Ms. Cindy Murray, Office Manager, Fountain Sanitation District, fsdistrict@fsd901.org

Mr. Jeff Burst, Project Supt., Weaver Construction Management, Inc., jeff@weavergc.com

Mr. John Jacob, Project Mgr., Weaver Construction Management, Inc., john@weavergc.com

Mr. Tyler Ammerman, Weaver Construction Management, Inc., tammerman@weavergc.com

Ms. Leslie Brown, Weaver Construction Management, Inc., leslie@weavergc.com

cc: Mr. Jerry Miller, Resident Project Representative, GMS, Inc.