

GMS, INC.
CONSULTING ENGINEERS
611 NORTH WEBER, SUITE 300
COLORADO SPRINGS, COLORADO 80903-1074

TELEPHONE (719) 475-2935
TELEFAX (719) 475-2938

EDWARD D. MEYER, P.E.
ROGER J. SAMS, P.E.
GREGORY R. WORDEN, P.E.
THOMAS A. McCLERNAN, P.E.

KEN L. WHITE, P.L.S.
DAVID R. FRISCH, P.L.S.
MARK A. MORTON, P.E.
JASON D. MEYER, P.E.

November 27, 2012

Mr. Wes Weaver, President
Weaver Construction Management, Inc.
3679 South Huron Street, Suite 404
Englewood, CO 80110

Via Email to: wes@weavercm.com
No Hard Copy to Follow

Re: Harold D. Thompson Regional Water Reclamation Facility (HDTRWRF)
Lower Fountain Metropolitan Sewage Disposal District (LFMSDD)

Dear Wes:

Reference is made to your shop submittal identified as follows:

Submittal No.:	05500-021
Date of Submittal:	November 20, 2012
Title:	MCC Support Rack
Specification Section:	05500 – Metal Fabrications
Manufacturer:	CSM Industrial Constructors

The referenced submittal has been stamped "***No Exception Taken***". Our comments are as follows:

1. We acknowledge the Additional Submittal Review Comments provided by WCMI.
2. The review comments indicate CSM has made the dimensions of the rack according to the specifications of MWI allowing for an extra 4 inches on each side of the MCC. We request the Contractor confirm with MWI that the 18'-3 $\frac{3}{8}$ " dimension shown on the shop submittal provides adequate length to accommodate the **eleven (11)** MCC sections.
3. Coordination is required between the contractor installing the handrail and the fabricated MCC support rack to ensure adequate clearance is provided between the wall-mounted handrails allowing sufficient room for the MCC support rack.

Please call if you should have any questions.

Sincerely,



David R. Frisch, P.L.S.

DRF/kmw

ec (letter only):

Mr. Jim Heckman, Manager, LFMSDD, lfmanager@lfmsdd.org
Ms. Cindy Murray, Office Manager, Fountain Sanitation District, fsdistrict@fsd901.org
Mr. Jeff Burst, Project Supt., Weaver Construction Management, Inc., jeff@weavercm.com
Mr. John Jacob, Project Mgr., Weaver Construction Management, Inc., john@weavercm.com
Mr. Adam Roeder, Weaver Construction Management, Inc., aroeder@weavercm.com
Ms. Leslie Brown, Weaver Construction Management, Inc., leslie@weavercm.com

cc (w/attachment): Mr. Jerry Miller, Resident Project Representative, GMS, Inc.