

**GMS, INC.**  
CONSULTING ENGINEERS  
611 NORTH WEBER, SUITE 300  
COLORADO SPRINGS, COLORADO 80903-1074

TELEPHONE (719) 475-2935  
TELEFAX (719) 475-2938

EDWARD D. MEYER, P.E.  
ROGER J. SAMS, P.E.  
GREGORY R. WORDEN, P.E.  
THOMAS A. McCLENNAN, P.E.

KEN L. WHITE, P.L.S.  
DAVID R. FRISCH, P.L.S.  
MARK A. MORTON, P.E.  
JASON D. MEYER, P.E.

May 24, 2013

Mr. Wes Weaver, President  
Weaver Construction Management, Inc.  
c/o Garney Construction  
7911 Shaffer Parkway  
Littleton, CO 80127

*Via Email to: [wes@weavercm.com](mailto:wes@weavercm.com)  
No Hard Copy to Follow*

Re: Harold D. Thompson Regional Water Reclamation Facility (HDTRWRF)  
Lower Fountain Metropolitan Sewage Disposal District (LFMSDD)

Dear Wes:

Reference is made to your shop submittal identified as follows:

Submittal No.:	05500-025
Date of Submittal:	March 22, 2013
Title:	Aluminum Handrail at Biosolids Handling Building
Specification Section:	05500
Manufacturers:	Golden Railings, Inc.; Sapa Extrusions; Pittsburgh Paint

The referenced submittal has been stamped "**No Exception Taken**". Our comments are as follows:

1. We acknowledge the Additional Submittal Review Comments provided by WCMI.
2. We acknowledge the alloy material proposed for use on the handrails is proposed to be the 6005-T5 alloy in lieu of the 6061-T6 alloy. Based upon the back-up documentation provided, both alloys are identical in strength and structural integrity. The back-up documentation also indicates the corrosion resistance is higher in the proposed alloy, 6005-T5. Therefore, we take no exception to the proposed alloy for the handrail.

Please call if you should have any questions.

Sincerely,



David R. Frisch, P.L.S.

DRF/kmw

ec (letter only):

Mr. Jim Heckman, Manager, LFMSDD, [lfmanager@lfmsdd.org](mailto:lfmanager@lfmsdd.org)  
Ms. Cindy Murray, Office Manager, Fountain Sanitation District, [fsdistrict@fsd901.org](mailto:fsdistrict@fsd901.org)  
Mr. Jeff Burst, Project Supt., Weaver Construction Management, Inc., [jeff@weavercm.com](mailto:jeff@weavercm.com)  
Mr. John Jacob, Project Mgr., Weaver Construction Management, Inc., [john@weavercm.com](mailto:john@weavercm.com)  
Mr. Adam Roeder, Weaver Construction Management, Inc., [aroeder@weavercm.com](mailto:aroeder@weavercm.com)  
Ms. Solange Huggins, Project Engineer, Garney Construction, [shuggins@garney.com](mailto:shuggins@garney.com)  
cc (w/attachments): Mr. Jerry Miller, Resident Project Representative, GMS, Inc.