

GMS, INC.
CONSULTING ENGINEERS
611 NORTH WEBER, SUITE 300
COLORADO SPRINGS, COLORADO 80903-1074

TELEPHONE (719) 475-2935
TELEFAX (719) 475-2938

EDWARD D. MEYER, P.E.
ROGER J. SAMS, P.E.
GREGORY R. WORDEN, P.E.
THOMAS A. McCLERNAN, P.E.

KEN L. WHITE, P.L.S.
DAVID R. FRISCH, P.L.S.
MARK A. MORTON, P.E.
JASON D. MEYER, P.E.

November 27, 2012

Mr. Wes Weaver, President
Weaver Construction Management, Inc.
3679 South Huron Street, Suite 404
Englewood, CO 80110

Via Email to: wes@weavercm.com
No Hard Copy to Follow

Re: Harold D. Thompson Regional Water Reclamation Facility (HDTRWRF)
Lower Fountain Metropolitan Sewage Disposal District (LFMSDD)

Dear Wes:

Reference is made to your shop submittal identified as follows:

Submittal No.:	08710-003C
Date of Submittal:	November 15, 2012
Title:	SSI for Hollow Metal Doors/Frames and for Finish Hardware at the Pumping and Disinfection Building
Specification Section:	08100 – Metal Doors and Frames 08710 – Finish Hardware
Manufacturer:	Cal-Royal Products, Inc.; Hager Co.; Ives; Pioneer Industries; Precision; Reese Enterprises; Stanley; Simplex; Schlage; Ilco

The referenced submittal has been stamped "**No Exception Taken**". Our comments are as follows:

1. We acknowledge receipt of the Additional Submittal Review Comments provided by WCMI regarding the resubmittal for doors and hardware and the P&D Building.
 - a. Comment No. 1: We acknowledge the vision lite proposed for door D-PD2 has been corrected to comply with CDPHE requirements.
 - b. Comment No. 2: The Contractor has provided notification in this submittal regarding Submittal No. 08710-004 that the vision lites proposed for the doors in the Operations Building will comply with ADA requirements.
2. Technical Data from Anemostat Door Products, 6"x34" Vision Lite: **No Exception Taken**
3. Modifications to Hardware Set B for door D-PD2: **No Exception Taken**
4. Door Design Dimension: **No Exception Taken**

Mr. Wes Weaver
November 27, 2012
Page 2

Please call if you should have any questions.

Sincerely,



David R. Frisch, P.L.S.

DRF/kmw

ec (letter only):

Mr. Jim Heckman, Manager, LFMSDD, lfmanager@lfmsdd.org

Ms. Cindy Murray, Office Manager, Fountain Sanitation District, fsdistrict@fsd901.org

Mr. Jeff Burst, Project Supt., Weaver Construction Management, Inc., jeff@weavercm.com

Mr. John Jacob, Project Mgr., Weaver Construction Management, Inc., john@weavercm.com

Mr. Adam Roeder, Weaver Construction Management, Inc., aroeder@weavercm.com

Ms. Leslie Brown, Weaver Construction Management, Inc., leslie@weavercm.com

cc (w/attachment): Mr. Jerry Miller, Resident Project Representative, GMS, Inc.