

GMS, INC.
CONSULTING ENGINEERS
611 NORTH WEBER, SUITE 300
COLORADO SPRINGS, COLORADO 80903-1074

TELEPHONE (719) 475-2935
TELEFAX (719) 475-2938

EDWARD D. MEYER, P.E.
ROGER J. SAMS, P.E.
GREGORY R. WORDEN, P.E.
THOMAS A. McCLERNAN, P.E.

KEN L. WHITE, P.L.S.
DAVID R. FRISCH, P.L.S.
MARK A. MORTON, P.E.
JASON D. MEYER, P.E.

October 31, 2012

Mr. Wes Weaver, President
Weaver Construction Management, Inc.
3679 South Huron Street, Suite 404
Englewood, CO 80110

Via Email to: wes@weavercm.com
No Hard Copy to Follow

Re: Harold D. Thompson Regional Water Reclamation Facility (HDTRWRF)
Lower Fountain Metropolitan Sewage Disposal District (LFMSDD)

Dear Wes:

Reference is made to your shop submittal identified as follows:

Submittal No.:	08710-004A
Date of Submittal:	October 25, 2012
Title:	Finish Hardware for the Doors at the Operations Building
Specification Section:	08710 – Finish Hardware
Manufacturer:	Cal-Royal Products, Inc.; Hager Co.; Ives; Kaba Ilco; Precision; Reese; Stanley

The referenced submittal has been stamped "**No Exception Taken**" and "**Make Corrections Noted**".
Our comments are as follows:

1. We take no exception to the doors and door hardware proposed for use on the Operations Building.
No Exception Taken
2. Door D-OP9 which represents the door from the corridor into the IT Server Room is labeled as receiving louvers by others. Please reference ESI-023 which indicates this door is to receive a single upper louver only. **Make Corrections Noted**
3. Door D-OP7 is listed as a left hand reverse door and noted as "Process Operations Center from Staff Work Room". This door should be labeled as "Process Operations Center to Staff Work Room" and be a left hand reverse door. **Make Corrections Noted**
4. All doors are to receive silencers which have not been indicated. However, we will assume they are being provided with each door. **Make Corrections Noted**

Please call if you should have any questions.

Sincerely,



David R. Frisch, P.L.S.

DRF/kmw

ec (letter only):

Mr. Jim Heckman, Manager, LFMSDD, lfmanager@lfmsdd.org
Ms. Cindy Murray, Office Manager, Fountain Sanitation District, fsdistrict@fsd901.org
Mr. Jeff Burst, Project Supt., Weaver Construction Management, Inc., jeff@weavercm.com
Mr. John Jacob, Project Mgr., Weaver Construction Management, Inc., john@weavercm.com
Mr. Adam Roeder, Weaver Construction Management, Inc., aroeder@weavercm.com
Ms. Leslie Brown, Weaver Construction Management, Inc., leslie@weavercm.com

cc (w/attachments): Mr. Jerry Miller, Resident Project Representative, GMS, Inc.