

GMS, INC.
CONSULTING ENGINEERS
611 NORTH WEBER, SUITE 300
COLORADO SPRINGS, COLORADO 80903-1074

TELEPHONE (719) 475-2935
TELEFAX (719) 475-2938

EDWARD D. MEYER, P.E.
ROGER J. SAMS, P.E.
GREGORY R. WORDEN, P.E.
THOMAS A. McCLERNAN, P.E.

KEN L. WHITE, P.L.S.
DAVID R. FRISCH, P.L.S.
MARK A. MORTON, P.E.
JASON D. MEYER, P.E.

October 10, 2011

Mr. Wes Weaver, President
Weaver Construction Management, Inc.
3679 South Huron Street, Suite 404
Englewood, CO 80110

Via Email to: wes@weavergc.com
No Hard Copy to Follow

Re: Harold D. Thompson Regional Water Reclamation Facility (HDTRWRF)
Lower Fountain Metropolitan Sewage Disposal District (LFMSDD)

Dear Wes:

Reference is made to your shop submittal identified as follows:

Submittal No.:	07200-001
Date of Submittal:	September 13, 2011
Title:	Vapor Barrier and Insulation for Batts and Ceilings
Specification Section:	07200
Manufacturers:	Owens Corning; Poly-America

The referenced submittal has been stamped "**No Exception Taken**" and "**Rejected**". Our comments are as follows:

- Owens Corning Thermal Batt Insulation – Unfaced Fiber Glass: **Rejected**
 - The project documents have a conformance specification of ASTM C665, Type II insulation, a faced insulation product.
- Owens Corning raft-R-mate® Attic Rafter Vents: **No Exception Taken**
- Owens Corning Quiet-Zone® Acoustic Batts:
 - This product information was included within the shop submittal; however, no product data or features have been checked. Therefore, we assume this is not to be considered part of this shop submittal. If it is to be included as part of the shop submittal, please check the appropriate technical data and resubmit.
- Poly-America Husky Plastic Sheeting: **No Exception Taken**

Mr. Wes Weaver
October 10, 2011
Page 2

Please call if you should have any questions.

Sincerely,

A handwritten signature in blue ink that reads "David R. Frisch". The signature is written in a cursive style.

David R. Frisch, P.L.S.

DRF/kmw

ec (letter only):

Mr. Jim Heckman, Manager, LFMSDD, lfmanager@lfmsdd.org

Ms. Cindy Murray, Office Manager, Fountain Sanitation District, fsdistrict@fsd901.org

Mr. Jeff Burst, Project Supt., Weaver Construction Management, Inc., jeff@weavergc.com

Mr. John Jacob, Project Mgr., Weaver Construction Management, Inc., john@weavergc.com

Ms. Leslie Brown, Weaver Construction Management, Inc., leslie@weavergc.com

cc: Mr. Jerry Miller, Resident Project Representative, GMS, Inc.